

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No. F6/DFS/MS/WZ/2024/ 25

Dated: 13/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Golden Flacon Industries Pvt Ltd** Located at Basement + Ground Floor Plot No. 71/03, Rama Road, Najafgarh Road, Industrial Area Near Moti Nagar, New Delhi-110015 in a building comprised of Basement + Ground + 01 Upper Floor owned/occupied by M/s. **Golden Flacon Industries Pvt Ltd**, was already issued FSC vide letter no. F6/DFS/MS/WZ/2021/588 dated 29/11/2021. The premises was re-inspected by officer concerned of this department on 19/12/2024 in the presence of Sh. Sachi Bhasin and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. the Owner/occupier have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 & the said premises is fit for occupancy class "Industry" Group G for Basement & Ground floor with effect from 13/01/2025 for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010 condition mentioned below.

Issued on.....13/01/2025.....at New Delhi by.

(Atul Garg)
Director

Copy to:

1. The Owner/occupier M/s. Golden Flacon Industries Pvt Ltd Plot No. 71/03, Rama Road, Najafgarh Road, Industrial Area Near Moti Nagar, New Delhi-110015.
2. The Executive Engineer (Building), SDMC, Shivaji Enclave, Rajouri Garden New Delhi-110027.

Following Fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building	M/s Golden Falcon Industries Limited located at Plot No. 71/3, Rama Road, Najafgarh Industrial Area New Delhi - 110015.
2. Type of Occupancy	G- 2 (Industrial)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2021/588 dated 29/11/2021.
5. Fire Safety directives letter No	F.6/DFS/MS/BP/2021/1050 dated 13/05/2021
6. Date of inspection	19/12/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Ms. Shachi Bhasin
9. Year of Construction	1957
10. Applicant's letter No.	Outdoor dairy No. 9004 dated 13/11/2024

The Said occupancy running at Basement & Ground Floor of a Building comprised of Basement, ground & 1st Floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	18 mts 4.5 mts NA	Provided Provided Provided	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 02	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 nos-1.25m(G to Terrace) 1nos-1.25m(G to 1 st Floor)	Provided	MR
		1.5 mts & 1.25 mts	Provided	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required NA	Provided NA	MR NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5 & 1.25 mts-basement, 1.25 mts each- upper floor.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan Provided Provided	MR MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR

81

N/27

6	First-Aid Hose Reels.			MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5 mm	Provided	
7	Automatic fire detection and alarming system.			MR
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	NA
9	Public Address System.	NA	NA	
10	Automatic Sprinkler System.			MR
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	NA
	• Sprinkler above false ceiling	NA	NA	
11	Internal Hydrants			MR
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	
12	Yard Hydrants.			MR
	• Total number of hydrants	02	Provided	MR
	• Hose Box	02	Provided	
13	Pumping Arrangements.			
	• Ground Level			MR
	> Discharge of main Pump	2280 LPM	Provided	MR
	> Head of Main pump	40 MH	Provided	MR
	> Number of main pumps	01	Provided	MR
	> Jockey Pump out put	180 LPM	Provided	MR
	> Jockey pump head	40 MH	Provided	MR
	> Standby Pump out put	2280 LPM	Provided	MR
	> Standby Pump Head	40 MH	Provided	MR
	> Auto Starting/ Manual stopping	Required	Provided	MR
	> Pump House Access	Required	Provided	MR
	• Terrace level			MR
	> Discharge of pump	900 PM	Provided	MR
	> Head of the pump	40MH	Provided	MR
	> Power Supply	Required	Provided	MR
	> Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,50,000 lts	Provided	MR
	> Draw-off connection	Required	Provided	MR
	> Fire service inlet	Required	Provided	MR
	> Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

BY

	Standby power supply	Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2021/588 dated 29/11/2021. renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~DCFO (w/12)~~

~~Signature of the Inspecting Officer~~
26/11/2024

45/ADO/MN
26/12/2024.

Signature of the Inspecting Officer
Name: - Sarajeet Singh
Designation: - ADO (MN)

Where is form 'J' & 'K'?

DCFO (w/12)
4.8.4.4.12
Dated 27/12/2024

~~ADO (MN)~~

~~Signature~~
26/12

in form J & K of filled format is placed at C-178, C-179

~~DCFO (w/12)~~

resubmitted pl. 1

~~Signature~~
04/1/25

345/ADO/MN
02/01/2025

~~Signature~~
06/01/2025

~~CFI~~
Directed
01/1/25

DCFO (w/12)
4.8.4.4.12
Dated 01/1/2025