

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 119

Dated: 06/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School, Ujwa, New Delhi-110073, comprised of ground floor only, having total 18 rooms (including class rooms, offices, Lab & exam hall etc.) owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2022/SZ/160 dated 11.02.2022. The school building was re-inspected by the officer concerned of this department on 30.01.2025 in the presence of Sh. Ajay Sharma, and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Director of Education and that the building/premises (**ground floor only**) is fit for occupancy class "**Educational Building**" with effect from 06/02/2025 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 06/02/2025 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service
 9/2/25 - 6/2/25
 4/2

Copy to: -

1. The Principal, Govt. Boys Sr. Sec. School at Ujwa, New Delhi-110073.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

10/12

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Sr. Sec. School, Ujwa, New Delhi-110073
2. Building comprised of : Ground floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/160 dated 11.02.2022
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 30.01.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Ajay Sharma
10. Year of Construction : Before 2010
11. Applicant's letter No. : Ref. No. GBSSS/UJWA/352 dated 09.01.2025

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement | Provided at site | Remarks MR/NMR |
|--------|--|---|--|-------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible 06 m 4.5 m N/A | Provided Directly accessible from road N/A | MR MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper Floor | N/A | N/A | N/A |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | e. Width of Corridor | 1.0 m | 1.05 & 1.17 to 1.20 m | MR |
| | f. Class Room Door Size | | (double door) | |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | Required | Natural Ventilation provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 11 No's ABC/CO ₂ type ISI marked | Provided | MR |
| | • Types | | Provided | MR |
| | • IS marking | | ISI marked | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |

N/14

| | | | | |
|-----|---|-----|-----|-----|
| | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2022/SZ/160 dated 11.02.2022, renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
3/2/2025

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~DO (SW)~~

R.K.
4/2/25

CFO
4/2/2025

Director
4/2/25

m