C 34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 1387 Dated: 09/12/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed. Sarvodaya Vidyalaya located at Sector- 13, Dwarka, New Delhi- 110078, is comprised of ground floor plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/SZ/2022/1129 dated 10.10.2022. The school building was re- inspected by the officer concerned of this department on dated 27.11.2025 in the presence of Ms. Seema Dabas (Principal), and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus three upper floors) is fit for occupancy class "Educational Building" w.e.f. 09/12/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 09/12/2025 at New Delhi by.

8/12/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Govt. Co-ed. Sarvodaya Vidyalaya at Sector- 13, Dwarka, New Delhi- 78.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed Sarvodaya Vidyalaya at Sector- 13, Dwarka, New Delhi- 110078.
2. Building comprised of : Ground plus three upper floors.
3. Type of Occupancy : Renewal
4. Details of Previous NOC/FSC : F.6/DFS/MS/SZ/2022/1129 dated 10.10.2022
5. Fire Safety directives letter No : N/A
6. Date of inspection : 27.11.2025
7. Name of Inspecting Officer : A.D.O. R.K. Yadav
8. Name and designation of officers From the building side : Ms. Seema Dabas (Principal)
9. Year of Construction : 2016
11. Applicant's letter No. : GCSV-13/DWK/2025-26/492 dated 12.11.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 10.10.2022	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	Accessible 06 m	60 m	M/R
	• Gate width	5.0 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	04 No	04 × 1.50 m	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 m each	04 × 1.50 m (including railing)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	04 nos.	04 nos.	M/R
	e. Width of Corridor	1.50 m	Provided	M/R
	f. Door Size	1.0 m	Provided	M/R
3.	**Compartmentation**			
	• Fire check door	Required	Provided in lift lobby	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	M/R
5.	**Fire Extinguishers**			
	• Total numbers	20 Nos.	Provided	M/R
	• Types	ABC/CO_2 type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R
6.	**First-Aid Hose Reels**			
	• Total numbers on each floor	04 no.	Provided	M/R
	• Length of hose reel hose	30 M	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R

W/21

7.	**Automatic fire detection and alarming system**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	Provided	N/A
9.	**Public Address System**	N/A	Provided	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	04 no's	N/A
	• Hose Box	N/A	Provided	N/A
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	06 no's	N/A
	• Hose Box	N/A	Provided	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	Provided	M/R
	➢ Head of the pump	40 mtr	Provided	M/R
	➢ Power Supply	Required	Provided	M/R
	➢ Auto Starting of pump	Required	Provided	M/R
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	N/A	50,000 ltrs	N/A
	➢ Draw-off connection	N/A	Provided	N/A
	➢ Fire service inlet	N/A	Provided	N/A
	➢ Access to tank	N/A	Provided	N/A
	• Overhead Tank capacity	10,000 ltrs	20,000 ltrs	MR
15.	**Exit Signage.**	Required	Provided	M/R
16.	**Provision of Lifts.**		**No Lift**	
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/22

		Required	Provided	MR
17.	**Standby power supply**			
18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/663 dated 20.08.2025 (placed at C-25) have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/SZ/2022/1129 dated 10.10.2022, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

01-12-2025

Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO (SW)
RAJINDER ATWALS

Dy. CFO (SZ)

2/12/25
A.K. MALIK
Principal Director

Dy. CFO to Commr.
02/12/25

Dy. CFO (SZ)

3/12/25
A.K. MALIK
DO (SW)

3/12
ADO (DWK)