



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

166



No. F6/DFS/MS/School/WZ/2026/ 32

Dated:- 11/03/2026

FIRE SAFETY CERTIFICATE


Certified that the Govt. Co-ed. Sr. Sec. School (New Building), located at Ladpur, Delhi-110081, comprised of Ground + 04 Upper Floors & MP Hall at 2nd Floor only, owned/occupied by Govt. Co-ed. Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 25/02/2026 in the presence of Ms. Asha Jonia (Vice-Principal) & Sh. Naveen Dabas (TGT) and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 11/03/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on ...11/03/2026 at New Delhi by



S.K. Dua

Dy. Chief Fire Officer (WZ)
Delhi Fire Service


11/03/26

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Co-ed. Sr. Sec. School, located at Ladpur, Delhi-110081.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Govt. Co-ed. Sr. Sec. School (New Building), located at Ladpur, Delhi-110081		
2.	Type of Occupancy	Educational Building (Group-B)		
3.	Building comprised of	Ground + 04 Upper Floors & MP Hall at 2 nd Floor		
4.	Type of Case	New case		
5.	Details of previous NOC	Nil		
6.	Fire Safety directives letter No	F6/DFS/MS/BP/2022/School/221 dated 13/05/2022		
7.	Date of inspection	25/02/2026		
8.	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (BW/RN)		
9.	Name and designation of officers from the building side	Ms. Asha Jonia (Vice-Principal) & Sh. Naveen Dabas (TGT)		
10.	Year of Construction	2022		
11.	Applicant's letter no.	54(SPS School)/PWD Edu. Sub-Divn M1-1(N)/2024-25/60 dated 18/10/2025		
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6.0 m	Provided	MR
		4.5 m	Provided	MR
		06 m & 09 m turning circles	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	05 NA	Provided NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2.0 m each NA	Provided NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Open able window	MR MR
	d. No. of continuous staircases to terrace	All	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1.20 m & 2.0 m x 2 for MP Hall	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required NA NA NA	Provided Provided NA NA NA	MR MR NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA Required	NA Natural Ventilation	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	60 nos. ABC/CO ₂ type Required	Provided Provided Provided	MR MR MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	05 nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement at some location	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	05 nos.	Provided	MR
	• Hose Box	05 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	05 nos.	NA
	• Hose Box	NA	Provided	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs.	Provided	MR
		Required	Provided	MR
15	Exit Signage.			

Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	Required	Provided
	• Lift Signage	Required	Provided
17	Standby power supply	Required	Provided
18 Refuge Area.			
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19 Fire Control Room			
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Battery backup	Required	Provided
	• Building Floor Plans	Required	Provided
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided

The fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/WZ/2024/School/719 dated 21/10/2024 found rectified.

Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures as required under the rules and it is **recommended** to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared & put up for approval please.

~~DO (WZ)~~
~~AA~~
 27/10/2026
 Dy CFO (WZ)

~~ADITHYAN~~
 27/10/2026
 Aman Kumar Lathar
 ADO (BW/RN)

~~Br. Director~~
 Rimp
 27/10/26

Dy. CFO to SSM.
 27/10/26

~~Dy. CFO (WZ)~~

F.T. please.
 Rimp
 27/10/26

~~ADO (BW)~~ F.T. letter is put up for your signature pl.

~~OCFO (WZ)~~
 Rimp
 27/10/26
 F.P. wing

~~Priya~~
 09/10/26