

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE


NEW DELHI-110 001.
 No. F.6/DFS/MS/School/2025/SZ/1198

Dated: 26/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls/Boys Sr. Secondary School at Mohan Garden, New Delhi-110059, comprised of two blocks namely Block-A & Block-B. Each blocks having ground plus one upper floor, owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/SZ/1078 dated 27.09.2022. The school building was re-inspected by the officer concerned of this department on dated 19.09.2025 in the presence of Ms. Bhawna Sagar (H.O.S), and found that School building have complied with the fire prevention and fire safety requirements in accordance with the Circular No. 3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational Building " w.e.f. 26/09/2025 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 26/09/2025 at New Delhi by.


 (Virendra Singh)
 Chief Fire Officer
 9/CF

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Govt. Girls/Boys Sr. Secondary School, Mohan Garden, New Delhi-59.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/10

INSPECTION REPORT

1. Name & address of the building	: Govt. Girls Sr. Secondary School, Mohan Garden, New Delhi-59.
2. Building comprised of	: Two Blocks-A & B. Both blocks having (G+1)
3. Type of Occupancy	: Educational
4. Type of Case	: Renewal
5. Details of Previous NOC	: F.6/DFS/MS/School/2022/SZ/1078 dated 27.09.2022
6. Fire Safety directives letter No	: Circular No. 3298 to 3398 dated 01.03.2011
7. Date of inspection	: 19.09.2025
8. Name of Inspecting Officer	: A.D.O. R.K. Yadav
9. Name and designation of officers From the building side	: Ms. Bhawna Sagar (H.O.S)
10. Year of Construction	: Before 2012
11. Applicant's letter No.	: Form "J" dated 31.08.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 m) 4.5 mtrs N/A	Provided 4.5 mtrs N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s in each block N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & .75 m N/A	1.38 & 1.44 m in Blk-A & 1.40 & 1.42 m in Blk-B N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 m	1.60 m	M/R
	f. Door Size	1.0 m	1.0 m (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 no's ABC type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A


RC


N/12


18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/1078 dated 27.09.2022, is recommended to be renewed in accordance to the Circular No. 3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (SW) 
23/9/25

CFO 
23/9/2025

Principal Director

CFO to 


22/09/25


CFO 

ADO (JKP)


24/9/2025

F T letter to put up for sign please


25/9/2025

CFO 
26/9/2025

My