



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/08

Dated: 03/01/2025

To,

The Principal,  
Govt. Girls Sr. Sec. School  
F-1, F-2, Nand Nagari Extn., (I- Block, Sundar Nagari),  
Delhi – 110093.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School located at F- 1, F-2, Nand Nagari Extn., (I- Block, Sundar Nagari), Delhi – 110093.**

Sir,

This has a reference to your Email dated 05/12/2024 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 18/12/2024 in the presence of Mrs. Nidhi Jain (HOS) and observed that school building comprised of ground plus one upper floor.

**Following shortcomings were observed during time of inspection:**

1. All Fire Extinguishers is found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Govt. Girls Sr. Sec. School located at F-1, F-2, Nand Nagari Extn., (I- Block, Sundar Nagari), Delhi – 110093.