

No. F6/DFS/MS/SCHOOL/SZ/2025/ 1419

Dated: 26/12/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School (Morning Shift)/ Govt. Boys Sr. Sec. School (Evening Shift) located at Bardarpur, Tajpur Pahari, New Delhi – 110044 School ID No. 1925359 (Morning Shift), School ID No. 1925360 (Evening Shift), Building ID No. 19251882, comprised of ground plus three upper floors was earlier granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2023/30 dated 12/01/2023. Now the school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 15/12/2025 in presence of Mrs. Vandana Bhardwaj (Principal) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of "Educational Building" with effect from 26/12/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance under Rules 28 of Delhi Fire Service Rule, 2010 printed below.

Issued on 26/12/2025 at New Delhi by.

  
(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service  
@ o/c

**Copy to: -**

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, Delhi – 110054.
2. The Assistant Engineer (E), PWD Sub-Division M1-PWD, Hauz Khas, New Delhi – 110016.
3. The Principal, Govt. Girls Sr. Sec. School located at Bardarpur, Tajpur Pahari, New Delhi – 110044.
4. The Principal, Govt. Boys Sr. Sec. School located at Bardarpur, Tajpur Pahari, New Delhi – 110044.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

41/25

**INSPECTION REPORT**

1	Name & address of the building	Govt. Girls Sr. Sec. School (Morning Shift)/ Govt. Boys Sr. Sec. School (Evening Shift) located at Bardarpur, Tajpur Pahari, New Delhi – 110044. School ID No. 1925359 (Morning Shift) School ID No. 1925360 (Evening Shift) Building ID No. 19251882
2	Building is comprised of	Ground plus three upper floors
3	Type of occupancy	Educational Building (Group -B)
4	Type of case	Renewal Case
5	Details of previous FSC	F6/DFS/MS/School/SZ/2023/30 dated 12/01/2023
6	Fire safety directives letter no.	NBC Part – IV & UBBL 2016
7	Date of inspection	15/12/2025
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Mathura Road
9	Name of the designation of officer from the building side	Mrs. Vandana Bhardwaj (Principal)
10	Year of construction	2018 -19
11	Applicant's letter no.	Online application 52025120200211

S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC/UBBL Requirement	Provided at site	Remarks MR/NMR	
<b>1</b>	<b>Access to Building:</b>				
<b>A</b>	Road width	6.0 meters.	6.0 meters.	MR	
<b>B</b>	Gate width	N/A	N/A	N/A	
<b>C</b>	Width of internal road	N/A	N/A	N/A	
<b>2</b>	<b>Number, Width, Type and Arrangement of Exits:</b>				
<b>A</b>	Number of staircases				
	a	Upper floor	05 Nos.	05 Nos.	MR
	b	Basement	N/A	N/A	N/A
<b>B</b>	Width of staircases				
	a	Upper floor	1.50 meters each	1.60 meters each	MR
	b	Basement	N/A	N/A	N/A
<b>C</b>	Protection of exits				
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
<b>D</b>	No. of continuous staircases to terrace	04 Nos.	04 Nos.	MR	
<b>E</b>	Width of corridor	1.50 meters	1.60 meters	MR	
<b>F</b>	Door size	1.0 meter x 02 nos. of each class room	1.0 meter x 02 nos. of each class room	MR	
<b>3</b>	<b>Compartmentation:</b>				
<b>A</b>	Fire check door	NA	NA	NA	
<b>B</b>	Sealing of electrical shafts	N/A	N/A	N/A	
<b>C</b>	Fire rating of shaft door	N/A	N/A	N/A	
<b>D</b>	Water curtain	N/A	N/A	N/A	
<b>E</b>	Fire dampers	N/A	N/A	N/A	
<b>4</b>	<b>Smoke Management System:</b>				
<b>A</b>	Basement	N/A	N/A	N/A	
<b>B</b>	Upper floor	N/A	N/A	N/A	

3

1116


<b>5. Fire Extinguisher:</b>				
A	Total numbers	30 No's.	135 No's.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI mark	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	05 nos.	05 nos.	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
<b>8 MOEFA:</b>		N/A	N/A	N/A
<b>9 Public Address System:</b>		N/A	Provided	N/A
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM	02 nos. of 450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters.	10,000 liters.	MR

Govt. Girls Sr. Sec. School (Morning Shift)/ Govt. Boys Sr. Sec. School (Evening Shift) located at Bardarpur, Tajpur Pahari, New Delhi - 110044

15	<b>Exit Signage:</b>	Required	Provided	MR
16	<b>Provision of Lifts:</b>			
	A Pressurization of lift shaft	N/A	N/A	N/A
	B Pressurization of lift lobby	N/A	N/A	N/A
	C Communication in lift car	N/A	N/A	N/A
	D Firemen's grounding switch	N/A	N/A	N/A
	E Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply:</b>	N/A	N/A	N/A
18	<b>Refuge Area:</b>			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/SZ/2023/30 dated 12/01/2023, renewal under Rule 37 of the Delhi Fire Service rules 2010, is **recommended**.

  
 15/12/2025  
 Signature of the Inspecting Officer:  
 Name Yashwant Singh Meena  
 Designation ADO/Mathura Roac

D.O/SD

*[Handwritten signature]*  
17/12/25

~~Dy. Insp.~~

*[Handwritten signature]*  
19/12/22  
**A.K. MALIK**  
Principal Officer

By. C.O. to Secy.

By. C.O. (S.A.)

*[Handwritten signature]*  
19/12/22

*[Handwritten signature]*  
21/12/22  
**A.K. MALIK**

*[Handwritten signature]*

*[Handwritten signature]*  
23/12/22  
**Ravinder Singh**