

C 35

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2025/NDZ/ 234

Dated: 11/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School located at F-1, F-2, Nand Nagari Extn., (1-Block, Sunder Nanari) Delhi-110093, school building comprised of Ground plus one upper floor and Ground plus three upper floors only (Two separate block), owned / occupied by Govt. Girls Sr. Sec. School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2022/NDZ/63 dated 24/01/2022. The premises was re-inspected by the officer concerned of this department on 27/02/2025 in the presence of Smt. Nidhi Jain (Vice-Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rules 33 of the Delhi Fire Service Rules, 2010 and found that the school building is fit for occupancy class "Educational" (Group-B) with effect from 11/03/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below.

Issued on 11/03/2025 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to :-

1. The Vice-Principal, Govt. Girls Sr. Sec. School, F-1, F-2, Nand Nagari Extn., (1-Block, Sunder Nanari) Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

2-19

1. Name & address of the building: Govt. Girls Sr. Sec. School, F-1, F-2, Nand Nagar Extn., (1-Block, Sunder Nanari) Delhi-110093
2. Type of Occupancy : Educational, Group-B(School)
3. Building Comprised of : A,B,C-block interconnected (G+1) & D-block (G+3) new
4. Type of Case : Renewal
5. Details of previous FSC No. F6/DFS/MS/School/2022/NDZ/63 dated 24/01/2022
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 27/02/2025
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer from the building side : Smt. Nidhi Jain (Vice-Principal)
10. Year of Construction : 2014-2017
11. Applicant's letter no received through email: dated 07/02/2025

S No	Minimum standards on fire prevention and fire safety U/R	NBC Part-IV requirement	Provided at site	Remarks MR/NMR
	33			
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	4.50 m	4.50 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floor Blk-A,B,C	5	5	MR
	• Upper floor Blk-D	2	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 mtr	1.50mx5 & 1.80mx2	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	2	MR
	c. Width Of Corridor	1.50 m	1.70m to 1.75m	MR
	d. Door Size	1.00m	1.10m & 1.20m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	24 Nos	36 Nos	MR
	• Types	ABC /Co <sub>2</sub>	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
		A		

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	2	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPMx2	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-1. Shortcomings issued by this department vide letter No. F6/DFS/MS/School/NDZ/2025/08 dated 03/01/2025 have been complied.

2. General requirements for schools as per Director of Education circular dated 1/03/2011 / NBC (Part-IV).

1. Escape route .....Clear.....
2. LPG cylinders in laboratories .....Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board .....Not under the  
staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2022/NDZ/63 dated 24/01/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok*  
28/01/2025  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East)

Dy. C.F.O. (NDZ)  
C.F.O.  
13/01/2025  
Director

*King*  
03/01/2025

FT. is added pl.  
Director  
10/1/25  
10/3/25