

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2025/ 848
2025

Dated: 27 / 11 / 2025

To,

The Principal,
Govt. Sarvodaya Bal vidyalaya,
Bijwasan Bharthal,
New Delhi.110077.

**Subject: Renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Bal vidyalaya, Located at
Bijwasan Bharthal New Delhi.110077.(School ID-1821032**

Sir,


Please refer to your Letter no :Bij/2025/534 Dated-18/08/2025 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 07/11/2025 in the presence of Sh. Shyam Sunder (St. Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:-

1. Hose reel found non functional due to nozzle missing.
2. Terrace level fire pump found nonfunctional.
3. Exit signage's found removed at some locations.

In view of the above shortcomings renewal of Fire Safety Certificate is rejected. & you are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(A.K. Malik)

Dy. Chief Fire Officer
South Zone

909

Copy to; -

The Directorate of Education, Old Secretariat, Delhi – 110054.