

c/54

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 42

Dated:- 17/01/2025

To,

The Principal,  
Govt. Sarvodaya Kanya Vidyalaya (ID-1617010),  
Nangloi, New Delhi-110041.

**Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya (ID-1617010), located at Nangloi, New Delhi-110041.**

Sir,

Please refer to your email dated 13/12/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 13/01/2025 in the presence of Ms. Veer Bala Malhotra (Vice Principal) & Sh. Sanjay Singh (Guard) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/2024/242 dated 16/05/2024.


During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to :-

  
14/11  
13/01/25

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ 242

Dated:- 16/05/2024

To,

The Principal,  
Govt. Sarvodaya Kanya Vidyalaya,  
Nangloi, New Delhi-110041.

**Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya (ID-1617010), located at Nangloi, New Delhi-110041.**

Sir,

Please refer to your letter no. GSKV/N/2024/280 dated 18/04/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 09/05/2024 in the presence of Sh. Davender Kumar Sharma (Estate Manager). During inspection, it has been observed that the school building is comprised of 03 blocks - Ground + 01 upper floor & 01 block - Ground + 03 upper floors. However, the following shortcoming has been observed:-

1. First Aid Hose Reel found non-functional.
2. Terrace pump of 450 lpm capacity found non-functional.
3. Domestic connection found drawn in Overhead water storage tank, shall be removed.
4. Electrical meters/panels found underneath the staircases, same shall be shifted on another safe place.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)  
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.