



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 356

Dated: 07/05/2025

To

The Assistant Engineer (E),
Sub-Division-4, Edu. Elect. Edn.-1, Div, (N)
PWD, Govt. of Delhi Room No. 03, First Floor,
Plot No-41, Rama Road, Zakhira, Delhi-110015.

Sub: Regarding issuance of fire safety certificate in r/o Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.

Sir,

Please refer to your letter No.54(45)/A.E.(E)-4/P.W.D/M-1/2024-25/05 dated: 10/03/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/04/2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that the building was comprised of ground & 03 upper floors only. At the time of inspection Sh. Pradeep Kumar (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Hose reel hose is provided but not functional and all hose reel nozzles found missing.
- 2 Terrace level fire fighting pump capacity of 450lpm is provided but not functional.
- 3 Terrace level water tank for firefighting capacity of 10,000 ltrs is provided but domestic connection is provided.
- 4 Exit signage is not provided at strategic locations in the school building.
- 5 Standby power supply is not provided.
- 6 Electrical panel below staircase needs to be removed/shifted in a safer place.
- 7 As built plan of the new school building shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of new school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. Principal, Govt. Sarvodaya Vidyalaya (School ID No- 1207032) located at Lancer Road, Near Vishwavidyalaya Metro Station, Delhi-110007.