

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/School/2025/NDZ/ 296

Dated: 28/04/2025

To

The Principal
Govt. Boys Sr. Sec. School (ID-1106258),
Harsh Vihar, Delhi-110093.

Sub.-: Regarding renewal of Fire Safety Certificate in r/o Govt. Boys Sr. Sec. School (ID-1106258), Harsh Vihar, Delhi-110093.

Sir,

Please refer to your letter No. GBSS/HV/2025-26/06 out door diary no. 543 dated 15/04/2025 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 24/04/2025 in the presence of Mrs. Indra (Principal) and observed that the shortcoming issued by this department vide letter No. F6/DFS/MS/School/2018/2507 dated 13/06/2018. (Copy Enclosed) still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Encl: as above


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/2018/ 2507

Dated 13/06/18

To,
The Vice Principal,
Govt. Girls Sec. School,
Harsh Vihar,
Delhi-110093

Sub:- Regarding renewal of Fire Safety Certificate in r/o Govt. Girls Sec. School, Harsh Vihar, Delhi 110093.

Sir,

This is in reference to your letter No. GGSS/HV/2018 dated 13/03/18 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Sudhanshu Kr. Singh, Estate Manager on dated 02/05/2018. During the course of inspection, the following points / shortcomings were noticed in the school building comprised of ground plus one upper floor.

1. Width of staircase should be 1.50 meter in each block or an additional fire escape staircase not less than 0.75 meter wide shall be provided in each block.

In view of above, the Fire Safety Certificate cannot be considered at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Vipin Kental)
Chief Fire Officer

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

o/c
