



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/Hospital/2026/NDZ/ 198

Dated: 02/09/2026

FIRE SAFETY CERTIFICATE

Certified that the **Goyal Hospital & Urology Centre** located at E-4/5 & 4/6, Krishna Nagar, Delhi- 110051, building comprised of Basement, Stilt, Ground plus three upper floors owned/occupied by Goyal Hospital & Urology Centre was earlier issued Fire Safety certificate from this department vide letter No. F.6/DFS/MS/Hospital/2023/NDZ/331 dated 10/07/2023. The premises was re-inspected by the officer concerned of this department on dated 28/07/2026 & 10/08/2023 in the presence of Dr. Vipin Rastogi and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premise have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit occupancy Class **"Hospital Building' Group "C-1"** with effect from 02/09/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on.....02/09/2026.....at New Delhi by.


29/9/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFICER

Copy to: -

1. Sh. Anil Goyal, Goyal Hospital & Urology Centre located at E-4/5 & 4/6, Krishna Nagar, Delhi- 110051.
2. The Directorate of Health Service, M.O. I/C Nursing Home Cell, Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-110032

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per NBC Part IV/BBL

INSPECTION REPORT

1. Name & address of the building : Goyal Hospital & Urology Centre,
E-4/5 & 4/6, Krishna Nagar, Delhi- 51
2. Building is comprised of : Basement + stilt + Ground plus three upper floors
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/Hospital/2023/NDZ/331 dt 10/07/2023
6. Fire Safety directive letter No : F.6/DFS/MS/BP/2022/177 dt 19/04/2022
7. Date of Inspection : 28/07/2026 & 10/08/2023
8. Name of the Inspecting officers : ADO (Shah.), Deepak Kumar
9. Name and designation of officer from the building side : Dr. Vipin Rastogi
10. Year of construction : 2021
11. Applicant's letter No : 52026042802567 dated 28/04/2026

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirements	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	12 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper floor	2.00 mtr. & 1.50 mtr	1.50 mtr & 2.00 mtr	MR
	• Basement	2.00 mtr. & 1.50 mtr	1.50 mtr & 2.00 mtr.	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
		N/A	N/A	N/A
	• Pressurization			
	d. No. of Continuous Staircases to Terrace	02 no.	02 no.	MR
	e. Width of Corridor	2.40 mtr	2.40 mtr	MR
	f. Door Size	2.00 mtr.	2.00 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	30 a/c per hour	Provided	MR
	• Upper floor	12 a/c per hour	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	12 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

2/18

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Ground	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	• Head of main pump	60 mtr	60 mtr	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	60 mtr	60 mtr	MR
	• Standby pump out put	1620 lpm	1620 lpm	MR
	• Standby pump head	60 mtr	60 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	900 lpm	900 lpm	MR
	• Head of the pump	60 M	60 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	75,000 ltr.	75,000 ltr.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltr.	20,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR

2

N/19.

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if Any:	N/A	N/A	N/A

The fire protection system provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/Hospital/2023/NDZ/331 dated 10/07/2023 **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Deepak
10/08/2026.

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shahdara)

DO (ED) *[Signature]*
10/08/26

CFO (East Zone)

[Signature]
11/8/26

Principal Director

CF to some plan
11/8/26

CFO (E2)

[Signature]
25/8/26

ADOL SHAH

Sir, P.T. letter is put up for your kind signature pl.

CFO (E2)

[Signature]
29/8/26

Deepak
28/08/2026

ms