


c/47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
No. F6/DFS/MS/EH/SZ/2026/ 222 Dated: 17/03/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Grand Kitchen** running at ground floor only of a building comprised of basement, stilt, ground plus three upper floors, located at GF, 2/6, East Patel Nagar, New Delhi-110008, was granted FSC vide letter No. F6/DFS/MS/EH/SZ/2023/118 dated 03.04.2023, The restaurant was re-inspected by the officers concerned of this department on dated 06.03.2026 in presence of Sh. Bijender (Manager), and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (Restaurant) (**running at ground floor only**) with effect from 17/03/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.
Issued on 17/03/2026 at New Delhi.


(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Online application Id 2026021001457 dated 18.02.2026.

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi. :- to inform about use of basement and a request to ensure the occupancy as detailed above and deviation, if any.

Conditions for validity of Fire Safety Certificate: -

1. **The FSC issued only for eating house/ restaurant running at ground floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The basement shall be used as per the building bye laws.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

113

INSPECTION REPORT

1. Name & address of the building : M/s. Grand Kitchen, GF, 2/6, East Patel Nagar, New Delhi.
2. Type of Occupancy : Assembly (Restaurant)
3. Building Composition : Said restaurant is running at ground floor of a building comprised of basement, stilt, ground plus three upper floors.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/SZ/2023/118 dated 03.04.2023
6. Fire Safety directives letter No : N/A
7. Date of inspection : 06.03.2026
8. Name of the Inspecting Officers : ADO R.K. Yadav (S.rd)
9. Name and designation of officers from the building side : Sh. Bijender (Manager)
9. Year of Construction : 2009 - 2010
10. Applicant's letter No. : Online Application id 2026021001457 dated 18.02.2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 03.04.2023	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02 nos	02 nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	2.0 & 1.5 mts	2.0 & 1.5 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	--	----	---
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 mts.	2.0, 1.5 mts	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements (other's property)	30 a/c per hour	N/A	N/A
	• Upper floors(Restaurant-GF)	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	• Total numbers	08	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on G. floor (Rest.)	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

11-

7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke/Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	GF	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Entire Restaurant 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	Provided (100 mm)	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	Provided (01 No.)	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	Provided (01 No.)	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumpng Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	---	---	---
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 mts	40 mts	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 lts	20,000 lts	MR
15	Exit Signage.	Required	Not Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A

N/A

	Standby power supply	Required	Provided	MR
MR	Refuge Area.			
N/A	➤ Total Area	N/A	N/A	N/A
N/A	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/SZ/2023/118 dated 03.04.2023, **renewal under rule 37** of the Delhi Fire Service Rules 2010, **is recommended.**

R.K. Yadav
 Signature of the Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (S.rd)

~~DO (SW)~~
[Signature]
 11/3/26
 RAJINDER ATWAL
 ADO (SZ)

[Signature]
 11/3/26
 A.K. MALIK
 Principal Director

my. cfo to Secy
[Signature]
 11/02/26

~~my. cfo (SZ)~~

[Signature]
 12/3/26
 A.K. MALIK
 DO (SW)
 12/3
 ADO (Srd)