

c28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No: F6/DFS/MS/EH/SZ/2025/ 97

Dated: 18/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of M/s **Haldiram Marketing Pvt. Ltd.** located at **L-43, Ground Floor, Kalkaji, New Delhi**, comprised of **Ground + 03 upper floors but restaurant at ground floor only** was granted FSC by this department vide letter no. F.6/DFS/MS/EH/2022/SZ/64 dated 09.03.2022. Now, the building/premises was re-inspected by the officer concerned of this department on 07.03.2025 in presence of Mr. Nitin Sharma (Manager) and found that the premises/building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of class (**Group-D**) "**Assembly Building**", **restaurant at ground floor only**, with effect from...18/03/2025 and valid upto 31.03.2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on18/03/2025.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
OK
52
18/03

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2025022002147 dated 24.02.2025.
2. The DHO, (South Zone), SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi - 110016.
3. The Licensee, M/s Haldiram Marketing Pvt. Ltd. at L-43, Ground Floor, Kalkaji, New Delhi.

Conditions for the validity of fire safety certificate

1. This FSC is valid for ground floor (restaurant) only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/s Haldiram Marketing Pvt. Ltd. located at L-43, Ground Floor, Kalkaji, New Delhi.		
2	Building is comprised of	Ground + 03 upper floors (Restaurant at ground floor only)		
3	Type of occupancy	Assembly Building-"Group-D"		
4	Type of case	Renewal		
5	Details of previous FSC	F.6/DFS/MS/EH/2022/SZ/64 dated 09.03.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	07.03.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Nitin Sharma (Manager)		
10	Year of construction	2014		
11	Applicant's letter no.	Online application no. 2025022002147 dated 24.02.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	UBBL/ NBC -2016 Requirements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	As per MPD-2021	06 m	MR
	Gate width	4.5 m	About on road	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases	Restaurant at ground floor only	
	a	Upper floor	NA	NA
	b	Basement	NA	NA
	B	Width of staircases		
	a	Upper floor	NA	NA
	b	Basement	NA	NA
	C	Protection of exits		
	a	Fire check door	NA	NA
	b	Pressurization	NA	NA
	D	No. of continuous staircases to terrace	NA	NA
	E	Width of corridor	NA	NA
	F	Door size	02 exits, 1.50 m x 2	Provided MR
3	Compartmentation:			
	A	Fire check door	NA	NA
	B	Sealing of electrical shafts	NA	NA
	C	Fire rating of shaft door	NA	NA
	D	Water curtain	NA	NA
	E	Fire dampers	NA	NA
4	Smoke Management System:			
	A	Upper floors	NA	NA
	B	Basements	NA	NA

5.	Fire Extinguisher:		10 nos.	Provided	MR
	A	Total numbers	ABC& Co2	ABC& Co2	MR
	B	Types	Required	Provided	MR
	C	ISI marking			
6	First-Aid-Hose Reels:		01 no.	Provided	MR
	A	Total numbers at each floor	30 mtr.	Provided	MR
	B	Length of hose reel hose	05 mm	Provided	MR
	C	Nozzle diameter			
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors	NA	Smoke type	NA
	B	Location of main panel	NA	Ground floor	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	Provided	NA
	E	Hooters Location	NA	Each floor	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor/ Gr. floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	size of riser/down-comer	100 mm	Provided	MR
	B	Number of hydrants per floor	Required	01 no.	MR
	C	Hose box	Required	01 no.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i	Pump House Access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	450 LPM	2 x 450 LPM	MR
	b)	Head of the pump	40 m	40 m & 30 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	20,000 ltrs.	Provided
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA-	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standard of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F.6/DFS/MS/EH/2022/SZ/64 dated 09.03.2022 is recommended to be renewed (restaurant at ground floor only), under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put for approval and signature please.

Sumit Kumar
10/03/2025

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (SD) *[Signature]* 10/3/25

CO (MS) *[Signature]* 11/3/2025

Director (MS) *[Signature]*

ADY Sanyal

F.T. letter is put up for signature, please.

Sumit Kumar
12/03/2025

Director (DFM) *[Signature]*

Uplanded
12/03/25