



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/SZ/GH/2025/213

Dated: 07/05/2025

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Haldiram Marketing Pvt. Ltd.
Located at C-9, Malviya Nagar, New Delhi-110017.**

Sir,

This has reference to MCD application ID No. 2025040305404 dated- 07/04/2025 on the subject cited above. In this connection, the premises have been re-inspected by the officer concerned of this department on dated 30/04/2025 in presence of Mr. Shansha, Manager. The Eating house is running ground plus two upper floors and building comprised of basement, ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Fire check doors not provided.
2. Doors are not installed.
3. Sealing of electrical shaft & fire rating shaft doors are not provided.
4. Smoke Management System are not provided.
5. Automatic Sprinkler systems are not provided.
6. An underground tank capacity 20,000 liters provided against requirement of 1,00,000 liters.
7. Exit Signage are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


**(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE**