



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

C-74



No. F.6/DFS/MS/WZ/EH/2026/166

Dated: 23/02/2026

To,

Mr. Satish Kaushik,
House No.F-51, Vishal Colony, Nangloi West,
Delhi-110041.

Sub: Renewal of FSC in r/o M/s Haldiram Marketing Pvt. Ltd., located at 17-A Shivaji Marg Najafgarh Road, Karmapura Moti Nagar, Delhi-110015.

Sir,

This is refer to online application no. 2026011700618 dated 21.01.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.02.2026, in presence of Mr. Naseer (Supervisor) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. The width of the alternate exit door was found to be less than the required 2.0 meters.
2. Fire Check Door (FCD) in the kitchen area was found removed.
3. The smoke management system in the basement and ground floor was found removed.
4. The smoke/heat detection system was found removed.
5. Concealed sprinkler plates were found permanently blocked with adhesive/putty, rendering the sprinklers non-functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully



(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service



Copy To:-

1. MCD Portal Id- 2026011700618 dated 21.01.2026.