



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C-31




No F 6 / DFS / MS / 2025/ School/WZ/1408

Dated: 19/12/2025


FIRE SAFETY CERTIFICATE

Certified that the H.D. Sehrawat Public School located at Plot No. 71-72, Satyam Vihar, Chanchal Park, Najafgarh Road, New Delhi-110043 comprised of Ground and Three upper floors was issued FSC by this department vide letter No F6/DFS/MS/WZ/School/2022/1294 dated 02.12.2022. The premises was re-inspected by the officer concerned of this department on 01.12.2025 in the presence of Sh. Ravinder Sehrawat (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Circular No. F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011/ NBC (Part-IV) and that the building/ premise is fit for occupancy Group B Educational with effect from .19.12.2025..... for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on19.12.2025 at New Delhi, by


18/12/25
(S.K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service



Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.
2. The Principal, H.D. Sehrawat Public School located at Plot No. 71-72, Satyam Vihar, Chanchal Park, Najafgarh Road, New Delhi-110043.
3. Online Application ID- 52025112600118.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : H.D. Sehrawat Public School located at Plot No. 71-72, Satyam Vihar, Chanchal Park, Najafgarh Road, New Delhi- 110043.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground + Three upper floors
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/School/2022/1294 Dated- 02/12/2022
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 01/12/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)
9. Name and designation of officers
From the building side : Sh. Ravinder Sehrawat (Manager)
10. Year of Construction : 2005 as per school performa given
11. Applicant's letter No. : Online Application No. 52025112600118 dated 26/11/2025

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated 21/11/2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5 m × 1 & 1.35 m × 1	1.5 m × 2 (G.F. to Terrace) & 1.25 m × 1 (G.F. to F.F.)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	7 Nos.	20 Nos.	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

A

127

	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

W

19. Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found some observations at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is **recommended to renew** the fire safety certificate issued vide letter no F6/DFS/MS/WZ/School/2022/1294 dated 02/12/2022 under Rule 37 of the Delhi Fire Service Rules, 2010.

ADO (JWP)
2/12/25

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO (Jawala Puri).

~~Do (WZ)~~ M
5/12

~~Dy C/O WZ~~

king
08/12/25

~~Pr. Director~~

My ADO to Secy.

~~My. C/O (WZ)~~

king
09/12/25

~~ADO (JWP)~~

Secy. FT letter in Dept for Secy. JWP

king
10/12/25

king
18/12/25

~~Dy C/O WZ~~

king
18/12/25

~~F.P. wing~~