



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F6/DFS/MS/2026/School/WZ/ 30

Dated: 11 /03/2026

FIRE SAFETY CERTIFICATE

Certified that the Holy Father Model School at Gole Market, Pratap Vihar-I, Delhi-110086 comprised of Ground & First Floor, but school is running at ground floor only, owned/ occupied by Holy Father Model School was issued Fire Safety Certificated vide this office letter No. F6/DFS/MS/2022/School/WZ/832 Dated: 02/08/2022. The premise was re-inspected by the officer concerned of this department on 13/02/2026 in presence of Mr. Ishaan Thakur and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School) for ground floor only" with effect from11.03.2026.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on11/03/2026... at New Delhi


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi - 110085.
2. The Manager, Holy Father Model School located at Gole Market, Pratap Vihar-I, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. This fire safety certificate is valid for ground floor only. In case of any violation, this FSC will be treated as null & void.

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building | : Holy Father Model School at Gole Market, Pratap Vihar-I, Delhi-110086. |
| 2. Type of Occupancy | : Educational |
| 3. Composition of building | : Ground & First Floor, But school is running at ground floor only |
| 4. Type of Case | : Add/Alt (Earlier it was ground floor now it is ground & first floor) |
| 5. Details of previous NOC | : F6/DFS/MS/2022/School/WZ/832 Dated: 02/08/2022 (ground floor only) |
| 6. Fire Safety directives letter No | : Nil |
| 7. Date of inspection | : 13/02/2026 |
| 8. Name of the Inspecting Officers | : ADO (Rohini) |
| 9. Name and designation of officers from the building side | : Sh. Ishaan Thakur |
| 10. Year of Construction | : 2020 |
| 11. Applicant's letter No. | : Online Mail-ID dated 10/02/2026 |


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV /UBBL Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible	Accessible	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
		01m	Provided	MR
	3	Compartmentation.		
<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		Required	Natural Ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06nos	Provided	MR
		ABC/Co2	Provided	MR
		ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	NA	Provided	NA
	• Nozzle diameter	NA	Provided	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	Provided	NA
	➤ Head of the pump	NA	Provided	NA
➤ Power Supply	NA	Provided	NA	
➤ Auto Starting of pump	NA	Provided	NA	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	NA	NA	NA
18	Refuge Area. <ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended for renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/832 Dated: 02/08/2022.


 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO (Rohini)

~~DO/NW~~



 26/02/2026

By CFO (WZ)
 P. Director

 27/02/26
 By. CFO to Insp.

By. CFO (WZ)
 ADO (Rohini)

F.T. please.

 03/03/26

As approved, F.T. letter is put up for your signature please.

 10/03/26
 F.P. wing

 09/03/2026