



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Hotel/SZ/2026/ 869

Dated: 14/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Hotel De Clark located at Kh. No. 845/3-4, Main Vasant Kunj Road, Mahipalpur, New Delhi -37.


Sir,

With reference to the MCD/MHA online application no. 2026073110194 on the subject cited above, it is informed that the said Guest House was inspected by officer concerned of this department on 21/08/2026 in the presence of Mr. Sanjay (Manager) and following shortcomings were observed.

1. Corridor width is 1.50 m provided against the requirement of clear width is 1.80 meters.
2. Lift signages has not been provided.
3. The plan uploaded with the application has not been signed & stamped by a registered architect.
4. The use and occupancy of the basement may be clearly indicated in the plan.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


10/9/26

(A.K. Malik)

Chief Fire Officer
Delhi Fire Service

7/ 10/9/26

Copy to:-

1. The Owner/Occupier/Manager, M/s Hotel De Clark located at Kh. No. 845/3-4, Main Vasant Kunj Road, Mahipalpur, New Delhi -37.