

c-115

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2025/260

Dated: 26/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Hotel Deep Palace situated at 7964/A, Arakashan Road, Pahar Ganj, New Delhi - 110055, comprised of Ground + 04 upper floors: Ground floor - (reception + 01 guest room), 1<sup>st</sup> floor to 3<sup>rd</sup> floor - (02 guest rooms at each floor) & 4<sup>th</sup> floor- (not in use). FSC was granted by this department vide letter no. F6/DFS/MS/GH/NDZ/2022/269 dated 08.06.2022 for total 07 guest rooms upto 3<sup>rd</sup> floor only. The building/premises was re-inspected by officer concerned of this department on 15.04.2025 in presence of Manager and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The owner has submitted an affidavit on 16.04.2025 stating not to use any floor above third floor for any purpose. Accordingly, the premises is fit for occupancy class (Sub Division-A-1) "Residential", ground floor - (reception + 01 guest room), 1<sup>st</sup> floor to 3<sup>rd</sup> floor - (02 guest rooms at each floor) for total 07 guest rooms upto 3<sup>rd</sup> floor only, with effect from 26/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on 26/04/2025 at New Delhi by

  
(Atal Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
25/4

**Copy to:-**

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2025031003210 dated 29.03.2025.
3. The Licensee, M/s Hotel Deep Palace at 7964/A, Arakashan Road, Pahar Ganj, New Delhi - 110055.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of above 3<sup>rd</sup> floor not allowed as per clause 7.31 in UBBL-2016.

## INSPECTION REPORT

1	Name & address of the building	M/s Hotel Deep Palace at 7964/A, Arakashan Road, Pahar Ganj, New Delhi.		
2	Building is comprised of	(Ground + 04 upper floors) Ground floor – (reception + 01 guest room) 1 <sup>st</sup> floor to 3 <sup>rd</sup> floor – (02 guest rooms at each floor) 4 <sup>th</sup> floor- (not in use as per affidavit dated 16.04.2025)		
3	Type of occupancy	Residential Sub Division-A-1		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2022/269 dated 08.06.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	15.04.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Manager		
10	Year of construction	1980		
11	Applicant's letter no.	Online application no. 2025031003210 dated 29.03.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	<b>Access To Building:</b>			
	Road width	Spl. Area (06 m)	12 ft. road & 20 m away from road	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
	a Upper floor	01 no.	01 no.	MR
	b Basement	NA	NA	NA
B	Width of staircases			
	a Upper floor	0.80 mtr.	Provided	MR
	b Basement	NA	NA	NA
C	Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	NA	NA	NA
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Upper floors	12 ACPH	Natural/ exhaust fan	MR
B	Basements	NA	NA	NA

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	08 nos.	08 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	Provided	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reels:</b>				
	<b>A</b>	Total numbers of each floor	01 no.	01 no.	MR
	<b>B</b>	Length of hose reel hose	30 m	30 m	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection And Alarming System:</b>				
	<b>A</b>	Type of detectors (CO type)	Required	Provided	MR
	<b>B</b>	Location of main panel	Required	Provided	MR
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	Required	Provided	MR
	<b>E</b>	Hooters	Ground floor	Provided	MR
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A</b>	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	<b>B</b>	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM	MR
	b)	Head of the pump	30 m	30 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14 Captive Water Storage For Fire Fighting:			
A	Underground tank capacity	NA	NA
B	Draw-off connection	NA	NA
C	Fire service inlet	NA	NA
D	Access to tank	NA	NA
E	Overhead tank capacity	2,500 ltrs.	2,500 ltrs. MR
15	Exit Signage:	Required	Provided MR
16 Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA
B	Pressurization of lift lobby	NA	NA
C	Communication in lift car	NA	NA
D	Firemen's grounding switch	NA	NA
E	Lift signage	NA	NA
17	Standby Power Supply:	Required	Provided MR
18 Refuge Area:			
A	Total area	NA	NA
B	Location	NA	NA
19 Fire Control Room :			
A	Detector system panel	NA	NA
B	Flow switch panel	NA	NA
C	Pa system panel	NA	NA
D	Battery backup	NA	NA
E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2022/269 dated 08.06.2022 is recommended to be renewed upto 3<sup>rd</sup> floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

*Sumit Kumar*  
19/04/2025

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD)

*[Signature]*  
21/4/25

*[Signature]*  
C.F.O

*[Signature]*  
21/04/25

*[Signature]*  
23/4/2025

*[Signature]*  
21/4/25

*[Signature]*