



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

C-91

No.F.6/DFS/MS/GH/SZ/2025/ 467

Dated: 03/12/2025

To,

Sh. Sangita Manchanda,
M/s Hotel Kashish Plaza, 12A/8, WEA, Saraswati Marg,
Karol Bagh,
New Delhi-110005.

Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s M/s Hotel Kashish Plaza, at 12A/8, WEA, Saraswati Marg, Karol Bagh, New Delhi-110005.


Sir,

This has reference to MCD application ID No. 2025110714655 dated 11/11/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 22/11/2025 in presence of Sh. Vivek. The premises is comprised of ground plus three upper floors & two rooms at terrace. The following shortcomings were observed during the time of inspection.

1. The two rooms found constructed on the terrace the plan submitted with application is not matching with the actual site. Further an undertaking that no floor above 3rd floor will be used for any purpose needs to be submitted with application.
2. First-Aid Hose reel is provided but not functional at the time of inspection.
3. MOEFA provided but not functional.
4. Terrace pump provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


3/12/25
(A. K. MALIK)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c
2

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi
MCD ID No. 2025110714655