



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/2
आफादीना
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2025/ 471

Dated: 5/12/2025

To

The Commissioner, MCD,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi-110002.

Ref: elt.mcdonline application no. 2025090413186.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Hotel Marigold (A Unit of Dreamfort Ventures Private Limited) located at Plot No. 11, Sector-10, Dwarka, New Delhi..


Sir,

With reference to the elt.mcdonline application no. 2025090413186 on the subject cited above, it is informed that the said Guest House was inspected by the officer concerned of this department on. 17.09.2025 in the presence of Mr. Narender Singh (Manager) and following shortcoming were observed at the time of inspection:

1. The width of main staircase is not meeting the requirement i.e. 1.50 meters.
2. Overhead tank having capacity of 15,000 litres has not been provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,


4/12/25

(A. K. Malik)

Dy. Chief Fire Officer (SZ)

o/c
06/10