



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F6/DFS/MS/2026/WZ/GH/07

Dated: 05/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/S Hotel Sona Deluxe located at 3611-3614, Dariba Pan, Pahar Ganj, Delhi-110055, comprised of stilt + 04 upper floors, 6 guest rooms at each floors, total-24 guest rooms was inspected by the officer concerned of this department on 24.12.2025 in the presence of Mr. Charan Singh Choudhary and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class Residential, Group A-1 with effect from 05/01/2026 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/01/2026 at New Delhi by


 (Dr. S. K. Tomar)
 Dy. Chief Fire Officer
 Delhi Fire Service
 ok 8/05/26

Copy to:

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2025112815244 dated 08.12.2025.
1. Mr. Charan Singh Choudhary, M/S Hotel Sona Deluxe located at 3611-3614, Dariba Pan, Pahar Ganj, Delhi-110055.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/S Hotel Sona Deluxe located at 3611-3614, Dariba Pan, Pahar Ganj, Delhi-110055.
2. Type of Occupancy	Assembled "D"
3. Comprised of building	Stilt + 04 upper floors
4. Type of Case	New Case (Stilt + 04 upper floors)
5. Details of Previous NOC	6 guest rooms at each floors, total-24 guest rooms only
6. Fire Safety directives letter No.	-NA-
7. Date of inspection	NBC Part-IV
8. Name of Inspecting Officer	24.12.2025
9. Name and designation of officers From the building side	Ajay Kumar Sharma ADO (Moti Nagar) Mr. Charan Singh Choudhary
10. Year of Construction	2025 on MCD Portal (New Case)
11. Applicant's letter No.	Online application No.2025112815244 dated 08.12.2025.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
-------	---	----------------------	------------------	----------------

1. Access to building

• Road width	PSS road	4m	MR
• Gate width	-NA-	-NA-	-NA-
• Width of internal road	-NA-	-NA-	-NA-

2. Number, Width, Type & Arrangement of Exits

a. Number of staircases

• Upper Floors	02nos.	Provided	MR
• Basements	-NA-	-NA-	-NA-

b. Width of staircases

• Upper Floor	1.5m each	2 x 1.5m	MR
• Basements	-NA-	-NA-	-NA-

c. Protection of exits

• Fire check door	-NA-	-NA-	-NA-
• Pressurization	-NA-	-NA-	-NA-

d. No. of continuous staircases to terrace

02nos.	Provided	MR
--------	----------	----

e. Width of Corridor

1.8m	Provided	MR
------	----------	----

f. Door Size

-NA-	-NA-	-NA-
------	------	------

3. Compartmentation

a) Fire check door	-NA-	-NA-	-NA-
b) Sealing of electrical shafts	-NA-	-NA-	-NA-
c) Fire Rating of shaft door	-NA-	-NA-	-NA-
d) Water Curtain	-NA-	-NA-	-NA-
e) Fire Dampers	-NA-	-NA-	-NA-

4. Smoke Management System

a) Basements	-NA-	-NA-	-NA-
b) Upper floors	Mechanical/ Natural	Exhaust fan	MR

5. Fire Extinguishers

a) Total numbers	10nos.	Provided	MR
b) Types	ABC/CO2	ABC/CO2	MR
c) IS marking	ISI marked	Yes	MR

6. First-Aid Hose Reels

a) Total numbers on each floor	01nos.	Provided	MR
b) Length of hose reel hose	30mm	Provided	MR
c) Nozzle diameter	5m	Provided	MR

7. Automatic fire detection and alarming system

a) Type of detectors	CO/smoke	Provided	MR
----------------------	----------	----------	----

		Required	Provided	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA	-NA-	Provided	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	Provided	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts..			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR

Refuge Area.			
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
19. Fire Control Room			
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:			
	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

(Signature)
 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Wazirpur/MN)

DO/CD) *(Signature)*
 26/12/25

Dy. CPO (NS2) *(Signature)*
 29/12/25

Principal Director

Dy. CPO to Secy. *(Signature)*
 02/01/26

Dy. CPO (NS2) *(Signature)*
 5/1/26

ADOL W.P. - On leave

F.T. letter is put up for signature; please.

Dy. CPO (NS2) *(Signature)*
 5/1/26

(Signature)
 05/01/2026

ms
U/Woded
 05/1/26

(Signature)