

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/SZ/2025/ 663

Dated: - 19/12/2025

FIRE SAFETY CERTIFICATE

Certified that the Auditorium Building located at ICAR & NASC Complex Pusa, New Delhi, comprised of Basement, Ground plus two upper floors, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2022/546 dated 06.12.2022. The building premises was re-inspected by the officer concerned of this department on dated 11.12.2025 in the presence of Sh. Susanth Nath, Executive Engineer (E) CPWD, and found that the building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (Basement, Ground plus two upper floors) is fit for occupancy Class-D (Assembly Building), w.e.f. 19/12/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 19/12/2025 at New Delhi by.


18/12/25
(A.K. Malik)
Dy. Chief Fire Officer
South Zone
2/1/25

Copy to:-

1. The Executive Engineer-I (Bldg.) HQ, SDMC, 9th floor, Civic Centre, Minto Road, New Delhi-110002.
2. Dy. Secretary, Ministry of Agriculture, ICAR & NASC Complex Pusa, New Delhi.

Following Fire Safety Directives Must Be Adhered To:-

1. Providing of fire safety measures does not give any guarantee that there will be No fire. These equipments/installation can minimize the losses if maintained in good working condition and handled efficiently in case of fire.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building	:	Auditorium at ICAR-NASC Complex, Pusa, New Delhi
2. Type of Occupancy	:	Assembly
3. Building Composition	:	Building comprised of basement, ground plus two upper floors
4. Type of Case	:	Renewal
5. Details of previous NOC	:	F6/DFS/MS/SZ/2022/546 dated 06.12.2022
6. Fire Safety directives letter No	:	F6/DFS/MS/BP/2013/534 dated 08.02.2013
7. Date of inspection	:	10.12.2025
8. Name of the Inspecting Officers	:	R.K. Yadav, ADO (SRD)
9. Name and designation of officers from the building side	:	Susanth Nath, Executive Engineer (E) CPWD
9. Year of Construction	:	Before 2019
10. Applicant's letter No.	:	DB(02)/DED-71/2025-26/3004 dated 13.11.2025


Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Guidelines	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	06 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Required	Provided	MR
	• Upper Floors	08 Nos.	Provided	MR
	• Basements	04 nos., 02 ramps	Provided	MR
	b. Width of staircases	Required	Provided	MR
	• Upper Floors	2.0 mts each	2.0 mts each	MR
	• Basements	2.0 mts each	2.0 mts each	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	04	04	MR
	g. Width of Corridor	2.0 mts	2.0 mts	MR
	h. Door Size	2.0 mts each	2.0 mts each	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	10 a/c per hour	Exhaust fan provided	MR
	• Upper floors/ Ground floor	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	• Total numbers	15	Provided	MR
	• Types	ABC & CO ₂ type	ABC & CO ₂ type	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	04 Nos	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7 Automatic fire detection and alarming system. Mg				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat	Provided	MR
		FCR	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Entire Building	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10 Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor / Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
11 Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	150 mm	MR
		04 Nos.	Provided	MR
		04 Nos	Provided	MR
12 Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	04 Nos.	04 Nos.	MR
		04 Nos.	04 Nos.	MR
13 Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	---	---	---
		2850 LPM	Provided	MR
		80 mts	Provided	MR
		02 Nos.	Provided	MR
		280 LPM	Provided	MR
		80 mts	Provided	MR
		2850 LPM	Provided	MR
		80 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-----	-----	-----
		900 LPM	450 LPM × 2	MR
		40 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14 Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000 lts	2,00,000 lts	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 lts	20,000 lts	MR
15	Exit Signage.	Required	Provided	MR
16 Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

Standby power supply		Required	Provided D.G set	MR
Refuge Area.				
➤ Total Area		N/A	N/A	N/A
➤ Location		N/A	N/A	N/A
Fire Control Room				
• Detector System Panel		Required	Provided	MR
• Flow Switch Panel		Required	Provided	MR
• PA System Panel		Required	Provided	MR
• Battery backup		Required	Provided	MR
• Building Floor Plans		Required	Provided	MR
Special Fire Protection Systems for Protection of special Risks, if any:		Required	02 ABC type fire extinguishers found Provided near elect. panel	MR


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F6/DFS/MS/SZ/2022/546 dated 06.12.2022, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.



 Signature of the Inspecting Officer
 Name:-R.K. Yadav
 Designation: - ADO (DWK)


~~DO (SW)~~


 15/12/25
 RAJINDER ATWAL
 Dy. CEO (SZ)


 15/12/25
 A.K. MALIK
 Principal Officer

My. CEO to Com.

 16/12/25

My. CEO (SZ)



 17/12/25
 A.K. MALIK
 Dtd (SZ)


 17/12
 ADO - BUK