



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2026/EZ/ 140

Dated: 01/09/2026

FIRE SAFETY CERTIFICATE

Certified that the **St. James School** at 8-A, Vijay Park, Yamuna Vihar, Delhi-110053, comprised of ground plus two upper floors but school running on ground plus one upper floor only, owned/occupied by St. James School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/NDZ/1750 dated 09/09/2019. The premise was re-inspected by the officer concerned of this department on 31/07/2026 in the presence of Sh. Mahesh Kumar (Manager) and found that the said building/premises have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class "Educational Group-B" with effect from 01/09/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 01/09/2026 at New Delhi by


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service
01/08/26

Copy to: -

1. The Manager, St. James School located at 8-A, Vijay Park, Yamuna Vihar, Delhi-110053.
2. The Deputy Director of Education, Govt. of National Capital Territory of Delhi, B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate:

1. This FSC is issued and valid for ground & first floor only. 2nd floor of the building shall not be used for any school activity, failing which this FSC shall be null and void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	St. James School located at 8-A, Vijay Park, Yamuna Vihar, Delhi-110053		
2.	Type of Occupancy	Educational, Group 'B-1'		
3.	Building Comprised of	Ground + 02 upper floors but the school is running on ground & 1 st floor only and school management has submitted an affidavit dated 05/08/2026 regarding not to use 2 nd floor.		
4.	Type of Case	Renewal		
5.	Details of previous FSC No.	F6/DFS/MS/School/2019/NDZ/1750 Dt 9/9/2019		
6.	Fire safety directives letter No.	DOE Circular No. 3298 to 3398 dated 01.03.2011		
7.	Date of inspection	31/07/2026		
8.	Name of the Inspecting Officer	ADO (Gokalpur)		
9.	Name and designation of Officer from the building side	Sh. Mahesh Kumar (Manager)		
10.	Year of Construction	1998		
11.	Applicant's letter No./Online Appn.	No. 52026072104606		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	- Road width - Gate width - Width of internal road	6.0 mtr N/A N/A	6.0 mtr N/A N/A	MR N/A N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	- Upper floors - Basements	01 No. N/A	02 Nos N/A	MR N/A
	b. Width of staircases			
	- Upper floors - Basements	1.50 mtr N/A	1.40m & 1.22m N/A	MR (Old case) N/A
	c. Protection of exits			
	- Fire check door - Pressurization	N/A N/A	N/A N/A	N/A N/A
	d. No of continuous staircase to terrace	01 No.	Provided	MR
	e. Width of Corridor	1.50 mtr	1.50 mtr	MR
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	- Fire check door - Sealing of electrical shafts - Fire Rating of shaft door - Water Curtain - Fire Dampers	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Managements System			
	- Basement. - Upper floors	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	- Total numbers - Types - ISI marking	04 Nos ABC & CO ₂ ISI marked	04 Nos Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	- Total numbers on each floor - Length of hose reel hose - Nozzle diameter	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

8/8

7.	Automatic fire detection and alarming system.			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants.	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit signage	N/A	N/A	N/A
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

SK

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

Note: The school building is comprised of ground plus two upper floors but the school is running at ground and first floor only. Further, Mr. Mahesh Kumar (Manager) of the school has submitted an affidavit regarding not to use 2nd floor for the school purpose.

The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection.**

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under DOE Circular No. 3298 to 3398 Dated 01/03/2011, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2019/NDZ/1750 dated 09/09/2019, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval and signature please.**


Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (Gokalpur)

DO (ED) 
07/08/26

CFO (East Zone) 
10/9/26

Principal Director CFO to issue, 
11/8

CFO (EET) 
24/9/26

Received on
24/8/26

ADO/G.P

Received on
31.08.26

Sir, F.T. letter is pending for your sig pl

CFO (EET) 
31/8/26


31.08.26

MS