



234
KFD
KFD

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6/DFS/MS/School/2025/NDZ/ 1388

Dated: 09/12/2025


FIRE SAFETY CERTIFICATE

Certified that the Jeewan Jyoti Public School located at Shaheed Bhagat Singh Colony, Pusta Road, Karawal Nagar, Delhi-110094, comprised of Ground plus three upper floors only but school is running ground plus two upper floors only, owned/occupied by Jeewan Jyoti Public School was issued FSC vide letter No. F.6/DFS/MS/2022/NDZ/School/805 dated 28/07/2022. The premises was re-inspected by the officer concerned of this department on 27/11/2025 in the presence Sh. Rakesh Kumar, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) (Ground plus two upper floors only) with effect from 09/12/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....09/12/2025.....at New Delhi by.


8/12/25

(Dr. S. K. TOMAR)

o/c  DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Manager, Jeewan Jyoti Public School located at Shaheed Bhagat Singh Colony, Pusta Road, Karawal Nagar, Delhi-110094

Conditions for the validity of Fire Safety Certificate: -

1. FSC is valid for ground plus two upper floors only. Third floor which is sealed may not be used for any purpose failing which FSC should be treated null and void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/12.

1. Name & address of the building : Jeewan Jyoti Public School
Shaheed Bhagat Singh Colony, Pusta Road, Karawal Nagar, Delhi-110094
2. Building is comprised of : Ground plus three upper floors but school is running
ground plus two upper floors only
3. Type of Occupancy : Educational, Group-B
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2022/NDZ/School/805
dated 28/07/2022 (G+2)
6. Fire Safety direction letter No. : NBC Part IV
7. Date of Inspection : 27/11/2025
8. Name of the Inspecting officers : Deepak Kumar, ADO (TP/Shd)
9. Name and designation of Officer
from the building side : Sh. Rakesh Kumar, Manager
10. Year of Construction : 2004
11. Applicant's letter No : Outdoor diary No. 5996 dated 15/09/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	Provided N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 nos. N/A	02 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.50 m N/A	1.50 m & 1.30 m N/A	MR (old case) N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 nos.	02 nos.	MR
	e. Width of Corridor	1.50 m	02 m	MR
	f. Door Size	01m	01m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A

R.

05.	Fire Extinguishers			
	• Total numbers	12 nos.	12 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- The school Manager has been submitted undertaking that the 3rd floor is sealed and not being used for school and any purpose.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the FSC issued vide letter no. F.6/DFS/MS/2022/NDZ/School/805 dated 28/07/2022 (G+2) **renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.**

Deepak
28/11/2025

Signature of the Inspecting Officer

Name :- Deepak Kumar

Designation :- A.D.O (TP/Shd)

DO(ED)

Principals
28/11/25

Dy. CPO (ESMA)
01/12/2025

Principal
Director

Dy. CPO to

Dy. CPO (RDX)

02/12/25

Jeewan Jyoti Public School, Shaheed Bhagat Singh Colony, Pusta Road, Karawal Nagar, Delhi-110094

A.D.O (TP)

3/12/25