



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 / School / WZ / 1272

Dated: 29/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Jesus Mary Joseph School located at G-17, Site 10, Paschim Vihar, New Delhi-110063 comprised of Ground and Three upper floors was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2022/948 dated 05.09.2022. The premises was re-inspected by the officer concerned of this department on 13.10.2025 in the presence of Mr. Mathew (Accountant), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule D.O.E. Circular No. 3298-3398 dated 01/03/2011/ NBC (Part IV), and the building/ premise is fit for occupancy Group B Educational with effect from ..29.10.2025.. for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on29.10.2025.. at New Delhi, by

S.K. Dua
(S.K. Dua)
29/10/25
Dy. Chief Fire Officer
all

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.
2. The Principal, Jesus Mary Joseph School located at G-17, Site 10, Paschim Vihar, New Delhi-110063.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-19
INSPECTION REPORT

- Name & address of the building : Jesus Mary Joseph School located at G-17, Site 10, Paschim Vihar, New Delhi- 110063.
2. Type of Occupancy : Educational
 3. Building Comprised of : Ground + Three upper floors
 4. Type of Case : Renewal
 5. Details of Previous NOC : F6/DFS/MS/School/WZ/2022/948 Dated- 05/09/2022
 6. Fire Safety directives letter No : F6/DFS/MS/BP/2013/357 Dated- 29/11/2013
 7. Date of inspection : 13/10/2025
 8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)
 9. Name and designation of officers :
 From the building side : Mr. Mathew (Accountant)
 10. Year of Construction : 2009-10 & 2015-16
 11. Applicant's letter No. : Diary No. 5674 dated 08/09/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated 12/08/2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.5 m × 5 (up to 2 nd floor) 1.5 m × 4 (up to 3 rd floor)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	04	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1 m (class room) 1.5 m (Hall)	1 m (class room) 2 m × 2 & 1.5 m × 1 (Hall)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	22 Nos.	Provided	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03 Nos.	04 Nos.	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	02	NA
	• Hose Box	NA	02	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm & 180 lpm	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked and found some observations at the time of inspection.
 Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is **recommended to renew** the fire safety certificate issued vide letter no F6/DFS/MS/School/WZ/2022/948 dated 05/09/2022 under Rule 37 of the Delhi Fire Service Rules, 2010.

[Signature]
 ADO/JWP
 15/10/25

Signature of Inspecting Officer
 Name : Rajeev Kumar Sinha
 Designation : ADO (Jawala Puri).

[Signature]
 M/ksa

[Signature]
 Dy (A/WZ) *[Signature]*
 17/10/25

[Signature]
 Principal Director Dy. Cfo to Jwp.

[Signature]
 Dy. Cfo (WZ) *[Signature]*
 22/10/25
 F.T. pl.

[Signature]
 ADO (JWP) *[Signature]*
 Bri. FT letter in pickup for sign sheet

[Signature]
 23/10

[Signature]
 ADO (JWP)
 28/10/25

[Signature]
 Dy Cfo (WZ) *[Signature]*
 29/10/25
 F.P. wing