

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 776

Dated: 12/06/2025

FIRE SAFETY CERTIFICATE

Certified that the **JR Public School**, running at ground plus two upper floors in a building comprised of ground plus three upper floors located at K-351/P-14, Shivpuri, Gali No. 2, West Sagarpur, New Delhi-110046, owned/occupied by JR Education Society (Regd.), was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2022/SZ/722 dated 29.06.2022. The school building was inspected by the officer concerned of this department on dated 03.06.2025 in the presence of Smt. Sushila Girsey (Manager), and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus two upper floors only**) is fit for occupancy class **"Educational Building"** w.e.f. 12/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 12/06/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service


Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054
2. The Manager, JR Public School at K-351/P-14, Shivpuri, Gali No. 2, West Sagar Pur, New Delhi-110046.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- N/B
1. Name & address of the building : JR Public School, K-351/P-14, Shivpuri, Gali No. 2, West Sagarpur, New Delhi- 110046.
 2. Building is comprised of : G+3 but school running at G+2 upper floors only.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/722 dated 29.06.2022
 6. Fire Safety directives letter No : Nil
 7. Date of inspection : 03.06.2025
 8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
 9. Name and designation of officers
From the building side : Smt. Sushila Girsey (Manager)
 10. Year of Construction : Before 2008 & 2019-20
 11. Applicant's letter No. : JRPS/126/2025 dated 16.05.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 M 4.5 m N/A	Provided Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.50 & .75 m N/A	1.60 & 1.16 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50 m.	1.50m	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 no's ABC/CO ₂ ISI marked	Provided Provided Provided	MR MR MR


M/S

6. Provision of Lifts.		No Lift		
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18. Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19. Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Note: - As per undertaking submitted by school management (placed at C- 27) that the school building is comprised of ground plus three upper floors but now the school running at ground plus two upper floors only.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2022/SZ/722 dated 29.06.2022, renewal in accordance with the Circular No. 262-362 dated 17/01/2005 issued by the Director of Education, is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

D.O. (South West)



5/6/25

CS/


5/6/2025

AD/18/20 