



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/Industrial/SZ/2025/ 578

Dated 2 | 12 | 2025

To

The Authorized Signatory,  
Fashion Maker International,  
Plot no. 87, FIE, Patparganj Industrial Area,  
Delhi-92.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s JSR Apparels Private Limited located at Plot no. 87, FIE, Patparganj Industrial Area, Delhi-92.

Sir,

With reference to the letter bearing outdoor diary no. 6383 dated 24.09.2025 on the subject cited above, it is informed that the said building was visited by officer concerned from this department on 18.11.2025 in the presence of manager and following shortcomings were observed:

1. All water based Systems like Fire Pumps, Hose Reels, Internal Hydrants, Sprinklers, are non-functional.
2. Additional Fire Pump of 450 LPM must be provided
3. Manual Operated Electrical Fire Alarm (MOEFA) system found removed.
4. Terrace water tank capacity of 15,000 liters not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(D. B. Mukherjee)

Dy. Chief Fire Officer (FSMA)

Copy to –

1. The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-110002.