

c 66

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F.6/DFS/MS/EH/2026/SZ/243 **NEW DELHI- 110001**

Dated: 24/03/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Jubilant FoodWorks Limited Dominos Pizza located at Gate No. 4, Shop No. 1, Shadipur Metro Station, New Delhi-110008, running at ground floor of Shadipur Metro Station, owned/occupied by M/s Jubilant FoodWorks Limited Dominos Pizza, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010. and verified by the officer concerned of this department on dated 12.01.2026 in the presence of the Manager, and found that the building is fit for occupancy Class 'D' 'Assembly Building' (ground floor only) w.e.f. 24/03/2026 with a period of three years, in accordance with Rule- 36 unless renewed under Rule- 37 or sooner cancelled under Rule- 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 24/03/2026 at New Delhi.



(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Online application Id 2026021801742 dated 19.02.2026.

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi. :- with a request to ensure the occupancy as detailed above and deviation, if any.

Conditions for validity of Fire Safety Certificate:-

1. The FSC issued only for eating house/ restaurant running at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Jubilant Foodworks limited Dominos Pizza located at Gate No. 4, Shop No. 1, GF, Shadipur Metro Station, New Delhi- 110008.
2. Building is comprised of : **Restaurant running at ground floor only.**
3. Type of Occupancy : **Group D (Assembly)**
4. Type of Case : **New Case (Eating House)**
5. Details of Previous NOC : **F.6/DFS/MS/SZ/2025/506 dt. 22.09.2025 (for Metro Station Building)**
6. Fire Safety directives letter No : **F.6/DFS/MS/BP/2004/2405 dt. 13.10.2004 (for Metro Station Building)**
7. Date of inspection : **12.03.2026**
8. Name of Inspecting Officers : **R.K. Yadav, ADO (SRD)**
9. Name and designation of officers
From the building side : **Manager**
10. Year of Construction : **2000 (As per online MCD application)**
11. Applicant's letter No. : **MHA Portal ID 2026021801742 dated 19.02.2026**

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | UBBL/NBC- 2016 Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--|---|-------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 06 m 4.5 m N/A | Provided Provided N/A | MR MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | Restaurant running at ground floor only | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A | N/A | N/A |
| | | N/A | Provided | N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | N/A | N/A | N/A |
| | f. Door Size | 1.50 m each (02 nos.) | 1.50 m each (03 Nos.) | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A | Provided | N/A |
| | | N/A | Sealed | N/A |
| | | N/A | 02 hours | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | N/A | N/A | N/A |
| | | 12 ACPH | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers in restaurant Types IS marking | 08 no.'s ABC/CO ₂ ISI marked | Provided ABC- 04 & Co2- 04 Provided | M/R M/R M/R |
| 6. | First-Aid Hose Reels | | | |
| | Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter | 02 Nos. 30 m 5 mm | Provided Provided Provided | M/R M/R M/R |

M/24

18

| | | | | |
|-----|--|-------------|-------------------|--|
| 7. | Automatic fire detection and alarming system in restaurant | | | |
| | <ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | Required | Smoke/Heat | M |
| | | Required | Provided | N/ |
| | | N/A | N/A | N/ |
| | | Required | Provided | N/A |
| | | Required | Provided | N/A |
| 8. | MOEFA | Required | Provided | M/R |
| 9. | Public Address System | N/A | Provided | N/A |
| 10. | Automatic Sprinkler System Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 11. | Internal Hydrants Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box | 100 mm | Provided | M/R |
| | | 02 no's | Provided | M/R |
| | | 02 no's | Provided | M/R |
| 12. | Yard Hydrants Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | 02 nos. | N/A |
| | | N/A | Provided | N/A |
| 13. | Pumping Arrangements Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | N/A | 1800 LPM | N/A |
| | | N/A | 60 mts | N/A |
| | | N/A | 01 | N/A |
| | | N/A | 180 LPM | N/A |
| | | N/A | 70 mts | N/A |
| | | N/A | 1800 LPM | N/A |
| | | N/A | 60 mts | N/A |
| | | N/A | Provided | N/A |
| | <ul style="list-style-type: none"> Pump House Access | N/A | Provided | N/A |
| | <ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | 900 LPM | Provided as above | MR (Pump at ground level at higher side) |
| | | 40 m | Provided as above | MR |
| | | Required | Provided as above | MR |
| | | Required | Provided as above | MR |
| 14. | Captive Water Storage for fire-fighting Provided & Maintain by Metro Station | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | 50,000 lts | 1,00,000 lts | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | 20,000 ltrs | Provided as above | MR (Tank at ground level at higher side) |
| 15. | Exit Signage. | Required | Provided | M/R |
| 16. | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| 17. | Standby power supply | Required | Provided | M/R |

18

N/25

| | | | | |
|-----|--|----------|---|-----|
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | Provided | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | Provided | N/A |
| | • Battery backup | N/A | Provided | N/A |
| | • Building Floor Plans | N/A | Provided | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | Required | Co2 trace tube fire extinguisher found provided for HT/LT elect. Panel. | MR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The FSC in respect of Metro Station Shadipur already issued vide letter No. F.6/DFS/MS/SZ/2025/506 dt. 22.09.2025. The restaurant running at Ground Floor of Metro Station Shadipur.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
 Signature of the Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (SRD)

DO (SW)
Raj
 20/3/26

RAJINDER ATWAL
 DeFO (SZ)

A.K. Malik
 20/3/26
 A.K. MALIK

Principal Architect

My. CFO to Insp.
[Signature]
 23/03/26

My. CFO (SZ)

A.K. Malik
 23/3/26
 A.K. MALIK
 DeFO (SW)

[Signature]
 23/3
 ADO