

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C 78

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2025/432

Dated:- 31/12/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. KAKAPO, located at Commercial Area, H-5/5, 2nd Floor, Ward No. 1, Kalka Das Marg, Mehrauli, New Delhi-110030 in a building comprised of ground floor + 02 upper floors, owned/occupied by Black Pants Hospitality LLP, was issued Fire Safety Certificate earlier in the name of Foreign Dhaba Modern Bistro & Bar by this department Vide Letter No. F6/DFS/MS/EH/2022/SZ/251 dated 07/09/2022. The restaurant premise was re-inspected by the officer concerned of this department on 26/12/2025 in the presence of Sh. Harender Singh and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" (Restaurant is running at 2nd floor only) with effect from 31/12/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 31/12/2025..... at New Delhi by.


(A.K. Malik)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002 :- in r/o computer id no. 2025121115604 dated 11/12/2025.
2. The Authorized Signatory, M/s. KAKAPO, Commercial Area, H-5/5, 2nd Floor, Ward No. 1, Kalka Das Marg, Mehrauli, New Delhi-110030.

Conditions for the validity of Fire Safety Certificate:-

1. This FSC is valid only for second floor.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

Pa DC
31/12/25

INSPECTION REPORT

2/10

1. Name & address of the building: M/s. KAKAPO (A Unit of Black Pants Hospitality LLP),
Commercial Area at H-5/5, 2nd floor, Ward No. 1, Kalka Das
Marg, Mehrauli, New Delhi-110030
 2. Type of Occupancy : Assembly Building "Group-D" (Restaurant at 2nd Floor)
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/EH/2022/SZ/251 dated 07/09/2022
 5. Fire Safety directives Letter No. : Nil
 6. Date of inspection : 26/12/2025
 7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (BW/RN)
 8. Name and designation of Officer
from the building side : Sh. Harender Singh
 9. Year of Construction : 2002 (as mentioned in online application)
 10. Applicant's online id no. : 2025121115604 dated 11/12/2025
- The building is comprised of ground + 02 upper floors but **restaurant is running at 2nd floor only.**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC-2016 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Abut on road	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 nos.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	2.0 m & 1.5 m	2.0 m & 1.5 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 m & 1.5 m	2.0 m & 1.52 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	Required	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor/Restt. Area	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet.	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A

20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A
-----	--	-----	-----	-----

2-12

N/A
N/A
A
L

The fire protection systems provided in the building were checked and found functional at the time of inspection. Further, the width of staircases are required of 2.0 & 1.5 meter as per NBC part-4 as the travel distance meeting with one staircase and same are provided, whereas in initial inspection Note (N-1 & N-6) requirement was mentioned 2.0 m & 1.0 meter. Now, same are corrected in this inspection Note .

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/EH/2022/SZ/251 dated 07/09/2022, renewal under rule 37 of the Delhi Fire Service Rule 2010, is **recommended**. Accordingly, DFA is prepared & put up for approval please.

Note:- Last disposal date of the case is 10/01/2026

[Signature]
27/12/25
Aman Kumar Lathar
ADO (BW/RN)

DO (SP)

[Signature]
29/12/25

~~DO (SP)~~

[Signature]
31/12/25
A.K. MALIK
Principal Director

By. CFO to *[Signature]*
[Signature]
31/12/25

By. CFO (SZ)
[Signature]
31/12/25

~~DO (SP)~~
~~DO (BW/RN)~~

F.T. letter is put-up for your signature /A,

[Signature]
31/12/25

~~DO (SP)~~

[Signature]
31/12/25
A.K. MALIK

M.S. cell

uploaded
31/12/25