



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

c/06

No.F6/DFS/MS/EH/NDZ/2025/ 472

Dated: 10/12/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding issuance of FSC in r/o M/s Kake Da Hotel (a unit of Food Destination) Located at HL-5, GF, L-Block, Jail Road, Anand Vihar, Hari Nagar, Delhi-110064.

Sir,

Please refer to online application No.202511114721 dated 18/11/2025, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officer concerned of this department on 27/11/2025 in the presence of Md. Shah Rukh Khan (Manager) and following shortcomings were observed: -

1. Overhead Water Storage tank capacity is 5,000 Ltrs. against required capacity of 20,000 Ltrs.
2. Automated operation of terrace pump is not provided.
3. Width of exit doors is 85 cms. each against required width of 1.5 mtr each.
4. MOEFA is provided but found non-functional.
5. Entry to the kitchen is not provided through Fire Check Door.
6. Complete drawing of the restaurant is not provided.

Keeping in view of the above **shortcomings**, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stand **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(A. K. Malik)
Dy. Chief Fire Officer

01c BP

Copy to: -

1. The Manager, M/s Kake Da Hotel (a unit of Food Destination), HL-5, GF, L-Block, Jail Road, Anand Vihar, Hari Nagar, Delhi-110064.