

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2025/WZ/ 252

Dated: 17/04/2025

To,

The Principal,
Kapila Public School,
2, Sandesh Vihar, Pitampura,
Delhi-110034.

Sub: - Regarding Issuance of Fire Safety Certificate in r/o Kapila Public School located at 2, Sandesh Vihar, Pitampura, Delhi- 110034.

Sir,

This has reference to your application no. KPS/MCD/FIRE/09/25 dated 25/02/2025 received through outdoor diary no. 12909 dated 25.02.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 15.04.2025 to see the compliance of shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2023/186 dated 17/04/2023. Smt. Poonam Wadhawan was present at the time of inspection.

During the course of inspection it was observed that the school is running on 1st floor in a building comprised of Ground plus two upper floors & school management have not complied the shortcomings till date of inspection.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2023/186

Dated: 17/04/23

To

The Principal,
Kapila Public School,
02, Sandesh Vihar, Pitampura
New Delhi- 110034.

**Sub: - Regarding issuance of Fire Safety Certificate in r/o Kapila Public School,
Located at 02 Sandesh Vihar, Pitampura, New Delhi – 110034.**

Sir,

Please refer to your Letter no. KPS/MCD/FIRE/07/23 dated: - 06/03/2023 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been re-inspected by the officer concerned of this department on 29/03/2023 in presence of Smt. Poonam Wadhawan (Principal) to check the shortcoming already issued by this department vide letter no. F.6/DFS/MS/School/WZ/2022/220 dated 13/05/2022.

The Status of shortcomings are as under:-

S. no.	Shortcomings	Status
1.	One additional staircase having width atleast 0.75mt is required.	Not Rectified
2.	Terrace pump is provided but not functional.	Not Rectified
3.	Hose reel hose is provided but not functional.	Not Rectified
4.	capacity of overhead water tank is less than required capacity of 2500 ltr.	Not Rectified

In view of above shortcomings the application for issuance of Fire Safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

17/04/23
13/4/2023