

046

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6/DFS/MS/2026/EH/NW/ 299

Dated: 02/04/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Karigari (A Unit of Karigari Restaurant Pvt.Ltd), located at No.M 21/31, Ground Floor & First Floor , Mall Road , Timarpur Civil Line , Delhi -110054 in a building comprised of basement,ground and 03 upper floors owned/occupied by M/s Karigari (A Unit of Karigari Restaurant Pvt.Ltd) was granted FSC by this department vide letter No.F.6/DFS/MS/2023/EH/307 dated 13/10/2023. The premises was re-inspected by the officers concerned of this department on 24/03/2026 in the presence of Mr. Hitesh Gaur and that the building/ premises is fit for occupancy Class "Group D Assembly (Restaurant) at Ground & First Floor only " with effect from 02/04/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule ,2010.

Issued on 02/04/2026..... at New Delhi by

  
02/04/26  
(S.K Dua)

Dy.Chief Fire Officer (WZ)  
Delhi Fire Service



Copy to: -

1. Online MHA portal ID No . 2026030902566.
2. M/s Karigari (A Unit of Karigari Restaurant Pvt.Ltd), located at No.M 21/31, Ground Floor & First Floor , Mall Road , Timarpur Civil Line , Delhi -110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

10/8

**INSPECTION REPORT**

1. N/Ame & address of the building	M/s Karigari (A unit of Karigari Restaurant Pvt.Ltd) at No-M21/31 GF & FF, Mall Raod, Timarpur Civil Line . Delhi - 110054			
2. Type of Occupancy	Assembly (Restaurant)			
3. Composition of building	Basement, Ground & 03 Upper floors, <b>Ground Floor, First Floor Restaurant only</b> , 2 <sup>nd</sup> & 3 <sup>rd</sup> floor owner resident.			
4. Type of Case	Renewal			
5. Details of Previous NOC	Vide letter No.F.6/DFS/MS/2023/EH/307 dated 13/10/2023			
6. Fire Safety directives letter No	Nil			
7. Date of inspection	23/03/2026			
8. N/Ame of Inspecting Officer	ADO(RN) Shri Paras Kumar & DO(NW) Shri A.k Jaiswal			
9. Name and designation of officers From the building side	Mr. Hitesh Gaur (Manager)			
10. Year of Construction	2006			
11. Applicant's letter No.	Online I.D No 2026030902566 dated 09/03/2026			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06m	20m approx...	MR
	• Gate width	N/A	N/A	N/A
	• Width of interN/AI road	N/A	N/A	N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02	03	MR
	• Basements	N/A	N/A	N/A
	<b>b. Width of staircases</b>			
	• Upper Floor	02 m & 1.50 m	02m & 1.50 m one additional iron staircase 1.50 m from ground to first floor	MR
	• Basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircases to terrace</b>	N/A	N/A	N/A
	<b>e. Width of Corridor</b>			
	<b>f. Door Size</b>	02 nos of each floor 02m&1.5 m	Provided	MR
3.	<b>Compartmentation</b>			
	a) Fire check door	N/A	N/A	N/A
	b) Sealing of electrical shafts	N/A	N/A	N/A
	c) Fire Rating of shaft door	N/A	N/A	N/A
	d) Water Curtain	N/A	N/A	N/A
	e) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	a) Basements	N/A	N/A	N/A
	b) Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers</b>			

	a) Total numbers	04 nos	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	a) Total numbers on each floor	01	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	a) Type of detectors	N/A	N/A	N/A
	b) Location of Main Panel	N/A	N/A	N/A
	c) Location of Repeater Panel	N/A	N/A	N/A
	d) AlterN/Ate source of power	N/A	N/A	N/A
	e) Hooters' Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	N/A	N/A	N/A
	b) Ground & Upper Floors	N/A	Provided	N/A
	c) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01	Provided	MR
	c) Hose Box	01	Provided	Mr
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	N/A	N/A	N/A
	b) Hose Box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	Terrace level			
	➤ Discharge of pump	450 LPM	450 PLM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity			
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity			
		20,000Ltr	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR

<b>16. Provision of Lifts.</b>			
a) Pressurization of Lift Shaft	N/A	N/A	N/A
b) Pressurization of Lift lobby	N/A	N/A	N/A
c) Communication In lift Car	N/A	N/A	N/A
d) Fireman's Grounding Switch	N/A	N/A	N/A
e) Lift SigN/Age	N/A	N/A	N/A
<b>17. Standby power supply</b>	Required	Provided	MR
<b>18. Refuge Area.</b>			
a) Total Area	N/A	N/A	N/A
b) Location	N/A	N/A	N/A
<b>19. Fire Control Room</b>			
a) Detector System Panel	N/A	N/A	N/A
b) Flow Switch Panel	N/A	N/A	N/A
c) PA System Panel	N/A	N/A	N/A
d) Battery backup	N/A	N/A	N/A
e) Building Floor Plans	N/A	N/A	N/A
<b>20. Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, the FSC issued Vide letter No.F.6/DFS/MS/2023/EH/307 dated 13/10/2023, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is recommended and recommended to **grant Fire Safety Certificate** under rule 35 (6) of the Delhi Fire Service Rule 2010.

Accordingly, DFA is put up for perusal and signature please.

*[Signature]*  
28/03/2026  
Signature of the Inspecting Officer  
Name - Shri Paras Kumar  
Designation ADO(RN)

*[Signature]*  
28/03/2026  
Signature of the Inspecting Officer  
Name - Shri A.K Jaiswal  
Designation DO(NW)

*[Signature]*  
Dy CFO (WZ)

*[Signature]*  
28/03/26

*[Signature]*  
Pr. Director

*[Signature]*  
My. CFO to Secm.

*[Signature]*  
My. CFO (WZ)  
F.T. please.

*[Signature]*  
ADO (RN) as directed FT is put up for signature  
28/03/26  
21/4/2026  
PTG