

C/45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2025/ School | 878
2025

Dated: 10 / 12 / 2025

To,

Mrs. Seema Srivastava (Principal), <kvdwarkaspg@kvsrodelhi.in>
Kendriya Vidhalaya,
Sector- 08, SPG Complex,
Dwarka, New Delhi.110077.

Subject: Renewal of Fire Safety Certificate in r/o Kendriya Vidhalaya Located at Sector- 08,
SPG Complex, Dwarka, New Delhi- 110077.

Sir,

Please refer to your Letter no 1432/07/KVSPG/2025-26/2303 Dated-17/11/2025 on the
subject mentioned above. In this connection it is to inform you that the premises was inspected by
the officer concerned from this department on 29/11/2025 in the presence of Mrs. Seema Srivastava
(Principal) from fire safety point of view.


The following shortcomings are observed during the time of inspection:-

1. Hose reel found non functional & nozzles found missing at some places.
2. Terrace pump found nonfunctional.
3. Exit signage's found removed at some locations.

You are requested to comply the above mentioned shortcomings under intimation to this
department for further consideration in the matter.

In view of the above shortcomings Fire Safety Certificate Cannot be considered at this stage.

Yours faithfully


(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to; - The, Directorate of Education Old Secretariat Delhi – 110054.