

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/NDZ/2025/ 64/ 270

Dated: 14/07/2025

FIRE SAFETY CERTIFICATE

Certified that the KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.) located at UGF-A 12, main road, Swami Dayanand Marg, East Krishna Nagar Delhi-110051, building comprised of Basement, Stilt, Ground plus Three Upper Floors But restaurant running on upper Ground Floor only, owned / occupied by A unit of Sapphire Foods India Pvt. Ltd., was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2022/NDZ/154 Dated 03/06/2022. The premises was re-inspected by the officer concerned of this department on 09/07/2025 in the presence of Sh. Imran (Manager) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) / Eating House with effect from 14/07/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 14/07/2025 at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to :-

1. Sh. Amit Nagpal, KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.) located at UGF-A 12, main road, Swami Dayanand Marg, East Krishna Nagar Delhi-110051.
2. Joint Commissioner of Police (Lic.) P. S. : Defence Colony, New Delhi-110024 w.r.t. MHA portal ID-2025070210779 dated 02/07/2025.

Conditions for the validity of Fire Safety Certificate:-

1. This Fire Safety Certificate is valid for Upper Ground floor only.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. The trained fire- fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: KFC Restaurant (A unit of Sapphire Foods India Pvt. Ltd.), UGF-A 12, main road, Swami Dayanand Marg, East Krishna Nagar Delhi-51.
2. Building is comprised of : Basement, Stilt, Ground + Three Upper Floors.
(But restaurant running on upper Ground Floor only).
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2022/NDZ/154 Dated 03/06/2022
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 09/07/2025
8. Name of the Inspecting Officer : Suman Kumar (A.D.O.)
9. Name and designation of Officer from the building side : Mr. Imran
10. Year of Construction : 2015
11. Applicant's MHA Portal No. : 2025070210779 dated 02/07/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NM R
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.50 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	2	4	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

N-13

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 Ltr	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2022/NDZ/154 Dated 03/06/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Suman Kumar
10/07/2025

Signature of the Inspecting Officer

Name : Suman Kumar

Designation : A.D.O.

~~DO (ED) Approval~~

~~Dy CFO (NDZ)~~

Singh
11/07/25

~~C.F.O~~
Wagh
11/07/25

~~Director~~
M
11/07/25