

24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/Ind./2025/NDZ/ 605

Dated: 09/12/2025

To,

Executive Engineer (MCD)
Building Department, Shahdara Noth Zone
3rd floor, Near Keshav Chowk, G. T. Road, Shahdara
Delhi-110053

Subject: - Regarding issuance of Fire Safety Certificate in r/o Storage building at Kh No. 9/1 & 9/2, Building No. M-1C, M-1A and M-2B Ground floor J.R. Complex, Gate No. 4, Village Mandoli, Delhi-110093

Sir,

With reference to your letter No. EE(B)/SH-N/2025/D-2606 dated 17/09/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 18/11/2025 in the presence of Sh. Sajjan Singh. The storage building comprised of ground floor (three separate blocks). During the course of inspection following observations were made:-

1. Automatic Fire Detection and Alarm system not provided.
2. Down-comer & Yard hydrant are not Provided.
3. Ground level Main pump & Standby pump capacity 2280 lpm head 70 meter and 180 lpm jockey pump head 70 meter not provided.
4. An underground water storage tank capacity 1,00,000 liters required not provided.
5. Draw-off connection & Fire service inlet not provided.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier, The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


8/12/25

(Dr. S. K. TOMAR)

ok 2
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE