



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



C-31



No. F6/DFS/MS/2026/CNG/WZ/04

Dated 06/01/2026

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station(IGL) located at Khasra No. 1A, DC Manglam Place, Sector-03, Rohini, Delhi- 110085 comprised of Ground floor only owned/ occupied by the Indraprastha Gas Limited have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 24/12/2025 in the presence of Sh. Dhruv Bhakhri (Manager) and that the building/premises is fit for occupancy Class "CNG Filling Station Group 'J' with effect from 06.01.2026... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06.01.2026 at New Delhi by


S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service


Copy to :-

1. Sh. Dhruvajit Bharali, General Manager (CNG Project), Indraprastha Gas Limited, IGL Bhawan, Plot No-4, Community Centre, Sector-09, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at Khasra No. 1A, DC Manglam Place, Sector-03, Rohini, Delhi-110085.
2. Type of Occupancy : CNG Filling Station Group 'J'
3. Type of Case : New
4. Composition of building : Ground floor only
5. Details of previous FSC : Nil
6. Fire Safety directives letter No : F.5/DFS/MS/CNG/BP/2023/342 dated 23/10/2023
7. Date of inspection : 24/12/2025
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers from the building side : Sh. Dhruv Bhakhri (Manager)
10. Year of Construction : --
11. Applicant's letter No. : IGL/CNGPRJ/FIRE/NOC Dated 14/11/2025


| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part-IV Requirements | Provided at site | Remarks MR/NMR |
|--------------|---|--------------------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 08m | 18m approx | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| f. Door Size | 1.0m | 1.0m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |


| | | | | |
|----|---|---|----------|-----|
| | <ul style="list-style-type: none"> Total numbers Types ISI marking | 02 trolley- 75 kg. 01 water mist cum foam trolley 06 CO2- 4.5kg | Provided | MR |
| | | DCP & Co2 | Provided | MR |
| | | Required | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |

| | | | | |
|----|---|---|-----|-----|
| | <ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Buckets filled with sand, No smoking boards were found displayed in Hindi & English. No lose electric wiring were seen in premises & Co2 flooding system found provided | | MR |
| 21 | DCP Spray System for Cascade | Provided | | MR |


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view of satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules and fire safety guidelines issued vide letter of even no. F.5/DFS/MS/CNG/BP/2023/342 dated 23/10/2023, it is recommended to grant Fire Safety Certificate.


 Signature of the Inspecting Officer
 Name: - C.L. Meena
 Designation:- ADO/Rohini

DO (NW)
 Dy CFO (NW)
 R. Director



 29/12/2025

Dy. CFO (NW)



 02/01/26
 P. S. S.