



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/01/2025
आपदा निव
अमृत महोत्सव

C-29

No. F6/DFS/MS/Hospital/2025/NDZ/ 89

Dated: 16 / 01 / 2025

To,

The Medical Superintendent,
Directorate General of Health Service,
Nursing Home Cell, 3rd Floor,
Delhi Government Dispensary Building,
S-1, School Block, Shakarpur,
Delhi -110090

Sub: - Issuance of Fire NOC in r/o KJIVF & Laparoscopy Centre, Plot No.-21, Gagan Vihar,
Delhi – 110092

Sir,

Please refer your letter No. F.24/New/ED/DGHS/NHC/2024-27/1701 dated 04.10.2024, received in this department. In this connection, it is to inform you that Delhi Fire Service had already issued a letter in this regard to DGHS vide letter No. F6/DFS/MS/BP/2019/Hospital/4680 dated 01/08/2019 (Copy enclosed).

Encl: As above

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/2
@A 50,

Copy to:-

1. Dr. Kuldeep Jain,
KJVF & Laparoscopy Center,
Plot No. 21, Gagan Vihar,
Delhi – 110051.

1

6-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE, NEW DELHI - 110001

NO. F.B/DFS/MS/BP/2010/ 1105 } 21/08/17 } 6 8 0

Dated 21/08/17

To,

The Director General Health Services,
Govt. of NCT of Delhi
F-17 Karkardooma, Delhi-32

Sub: Issuance of Fire NOC in r/o Day Care establishments such as Eyo Centrol/
Dental Clinics/Dr. Clinic / OPD /Lab from fire safety point of view : reg.

Sir,

This department is receiving many requests from the occupiers /owners of Eyo Centre/Dental Clinic/ OPD/ laboratories for issuance of Fire NOC, as they have been issued Show Cause Notice from Directorate General of Health Services . In this regard it is to inform you that the Day Care establishments such as Eyo Centrol/ Dental Clinic / Doctor's Clinic / OPD centre /Diagnostic LAB, if they are not having sleeping facilities /nigh stay for the patient in their Centers/Clinic, are categorized under business occupancy (as per clause 3.1.6 of National Building Code Part-4/2016) and business building having height less than 15 meter or less than ground plus four upper stories including mezzanine is not covered under Rule 27(7) of DFS Rules 2010 under DFS Act 2007. Hence, NOC/ Fire Safety Certificate to above said occupancies is not required from this department. Moreover, Nursing Home having height less than 9 meter or less than ground plus two upper floor are also not required to obtain Fire Safety Certificate / NOC from this department.

Yours faithfully


(Vipin Kantil)
Director
Delhi Fire Service
Ph. 011-23414000

