



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

CT*



No. F.6/DFS/MS/WZ/GH/2025/ 181

Dated: 17/4/25

To,

Mr. Kulbhushan Arora,
House No.EA-48,
Inder Puri,
New Delhi-110012.

Sub: Renewal of FSC in r/o M/s Krishna DX. located at Shop No.5589, Basant Raod, Pahar Ganj, New Delhi-110055.

Sir,


This is reference to online application no. 2025031803857 dated 18.03.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **07.04.2025**, in presence of **Mr. Upender (GM)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose reel provided but not functional.
2. Terrace Fire pump with capacity of 225 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Virendra Singh)
Chief Fire Officer
for DIRECTOR
Ph; 011-23414000

Copy To:-

1. MCD Portal Id- 2025031803857 dated 18.03.2025.