



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

Dated: 13/02/26

No. F6/DFS/MS/BNQT/NDZ/2026/ 132

To

The Commissioner,  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Centre, Minto Road,  
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) located at Property no. 44, Ground floor, Hasanpur, Shahdara, New Delhi.

Sir,

With reference to the etl.mcdonline application no. 2026011200396 on the subject cited above, it is informed that the said Banquet Hall was inspected by officer concerned of this department on 10/02/2026 in the presence of Mr. Lalit Chauhan (Owner o the Banquet Hall) and following shortcomings were observed: -

1. Fire check doors found removed.
2. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
3. All water based systems like Hose Reel, Down Comer System & Terrace fire pump are found non functional.
4. The combustible furnishing at rear exit must be removed.
5. Auto starting of fire pump found removed.
6. An additional terrace water tank of 5000 litres shall be provided to meet the total requirement of 25000 litres terrace water tank capacity.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
13/2/26

(Dr. S. K. Tomar)

Dy. Chief Fire Officer

o/c Bldg