



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Bnqt/2025/NDZ/ 183

Dated: 07/11/2025

To

The Commissioner,  
Municipal Corporation of Delhi,  
Dr. SPM Civic Centre, JLN Marg,  
Minto Road, New Delhi-110002.

**Sub:** Regarding issuance of Fire Safety Certificate in r/o M/s Le Paradise at Property No. 341/6B/1, GF, Kanti Nagar, Delhi-110051.


Sir,

This has a reference to online ID **2025100413954** dated 08/10/2025 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 19/10/2025 in the presence of Himanshu, Manager to verify the compliance of the shortcomings issued vide letter No. F.6/DFS/MS/BNQT/2025/NDZ/147 dated 19/08/2025 and observed that the shortcomings are still not complied. (Copy enclosed)

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

Encl.- As above

  
( Dr. S. K. Tomar )  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Nodal Officer/Delhi Fire Service with the request to upload on MCD portal.
2. Mr. Akshay Goyal (Manager) M/s Le Paradise at Property No. 341/6B/1, GF, Kanti Nagar, Delhi-110051.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Bnqt/2025/NDZ/ 147

Dated: 19/08/2025

To

The Commissioner,  
Municipal Corporation of Delhi,  
Dr. SPM Civic Centre, JLN Marg,  
Minto Road, New Delhi-110002

**Sub:** Regarding issuance of Fire Safety Certificate in r/o M/s Le Paradise at Property No. 341/6B/1, GF, Kanti Nagar, Delhi-110051

Sir,

This has reference to online portal application No. 2025072111675 dated 22/07/2025. In this connection, it is to inform you that the premise was visited by the officers concerned of this department on 01/08/2025 to verify the compliance of shortcomings already issued by this office vide letter No. F.6/DFS/MS/2025/WZ/BNQT/122 dated 14/07/2025 in the presence of Mr. Akshay Goyal (Manager). During course of inspection, **the status of shortcomings observed is as below.**

S. No.	Shortcomings issued	Present Status
1.	Alternate staircase serving upper floors is provided of 1.0 mtr against the requirement of 1.5 mtr and also not provided up to terrace level.	Not complied
2.	02nos of hose-reel & hydrant are required at each floor, whereas only 01nos of hose-reel and hydrant is provided.	Not complied
3.	Overhead tank is provided of 10,000 liters against the requirement of 20,000 liters.	Not complied
4.	Exit signage's are not provided.	Not complied

In view of above non-compliance, application for **issuance of fire safety certificate cannot be considered at this stage & rejected.** The occupancy of the building/premises in the absence of requisite fire protection measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
18/8/25  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Nodal Officer/Delhi Fire Service.....with the request to upload on MCD portal.