



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 1287

Dated:- 04/11/2025

FIRE SAFETY CERTIFICATE

Certified that the L.K. International School, located at Auchandi Road, Bawana, Delhi-110039 is running on Single Block (Basement + Ground + 02 Upper Floors only) in a building comprised of Two Block (Basement + Ground + 02 Upper Floors & Ground + 01 Upper Floor), owned/occupied by L.K. International School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2022/School/WZ/901 Dated 18/08/2022. The said premise was re-inspected by the officer concerned of this department on 16/10/2025 in the presence of Sh. Lalit Kumar Gupta (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 04/11/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on ...04/11/2025... at New Delhi by.


S.K. Dua
Dy. Chief Fire Officer (WZ)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, L.K. International School, located at Auchandi Road, Bawana, Delhi-110039

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per RBI..

INSPECTION REPORT

1. Name and address of the building: L.K. International School, located at Auchandi Road, Bawanani, Delhi-110039
2. Type of Occupancy : Educational, 02 Block, Basement+Ground+02 Upper Floor & Ground+01 Upper Floor, School is running at single block - Basement+Ground+02 Upper floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2022/School/WZ/901 Dated 18/08/2022
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 16/10/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (BW/RN)
8. Name and designation of Officer from the building side : Sh. Lalit Kumar Gupta, (Manager)
9. Year of Construction : 2004 & 2012
10. Applicant's letter No. : LKIS/25-26/2609 dated 26/09/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Fire Safety Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	06 m	06 m	MR
	• Road width	4.5 m	4.5 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road			
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02	02	MR
	• Upper floors	02	03	MR
	• Basements			
	b. Width of staircases	1.5 m each	1.5 m each	MR
	• Upper floors	1.5 m each	1.5 m each	MR
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization	01	Provided	MR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	1.5 m	1.50 m	MR
	f. Door Size	1 m	1.10 m	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	Required	Natural Ventilation	MR

5.	Fire Extinguishers			
	• Total numbers	18 nos.	21 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	Provided	NA
	• Number of hydrants per floor	NA	02	NA
	• Hose Box	NA	02	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	1000 lpm	Provided	MR
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided	MR

Fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2025/WZ/731 dated 17/09/2025 found rectified.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/2022/School/WZ/901 Dated 18/08/2022, renewal under rule 37 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly, DFA is put up for approval & signature please.

[Signature]
21/10/25
Aman Kumar Lathar
ADO (BWN/RN)

[Signature]
Approval
21/10/25

By CFO (ND2) *[Signature]*
22/10/25

Principal Director

My. Cfo to *[Signature]*

My. Cfo (ND2) *[Signature]*
22/10/25

Area belongs to D(CFO(w2))

D(CFO(w2))
ADO (BWN/RN)

F.T. pl.

[Signature]
23/10/25

[Signature]
24/10

ADO (Bawana)

F.T. letter is put-up for your signature pl.

[Signature]

[Signature]
25/10/25

[Signature]
25/10/25

F.P. wing