

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2025/School/WZ/251

Dated: 18/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **M. C. Primary Co-Ed School, Sector-17-B, Rohini, Delhi-110089**, comprised of **04-Blocks, Ground + One upper floor** owned/occupied by **M. C. Primary Co-Ed School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2021/School/WZ/1045** dated **21.12.2021** The premises was re-inspected by the officer concerned of this department on **07.03.2025** in the presence of **Smt. Usha Chaudhry (In-charge)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 18/03/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 18/03/2025 at New Delhi

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000  
AK  
AK

Copy to: -

1. The Director, Education, North MCD, Civic Center, New Delhi .
2. The Principal, M. C. Primary Co-Ed School, Sector-17-B, Rohini, Delhi-110089.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : M. C. Primary Co-Ed School, Sector-17-B, Rohini, Delhi-110089.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (04 Blocks, Ground + 01 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2021/School/WZ/1045 dated 21.12.2021
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 07.03.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Mrs. Usha Chaudhry (Ic-charge)
9. Year of Construction : 2005
10. Applicant's letter No. : Online e-mail dated 20.01.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. Of Educational	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	d. Number of staircases			
	• Upper Floors	06nos.	07nos.	MR
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases			
	• Upper Floor	A-blk-1x1.5m B-blk-2x1.5m C-blk-1x1.5m D-blk-2x1.5m	A-blk-2.10m B-blk-2x1.60m C-blk-2x1.45m D-blk-2x1.65m	MR
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	15nos.	Provided.	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	-NA-	-NA-	-NA-
	• Length of hose reel hose	-NA-	-NA-	-NA-
	• Nozzle diameter	-NA-	-NA-	-NA-
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	-NA-	-NA-	-NA-

24



<ul style="list-style-type: none"> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
	NA	NA	NA
	-NA-	-NA-	-NA-
	-NA-	-NA-	-NA-
<b>Special Fire Protection System for Protection of special Risks, if any:</b>			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/2021/School/WZ/1045 dated 21.12.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*Ajay Kumar Sharma*  
 Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO (Rohini)

~~DO (NW)~~

*Ajay*  
 10/03/2025

*By CFO (WZ)*

*Ajay*  
 10/13/2025

*S.B. M.D.*  
*10/3/2025*

*CFO*  
*Vinod*  
 11/31/2025

*Director*  
*Ajay*  
 11/03/25

*Ajay K*

FI letter is put up for kind  
 perusal and signature please

*Director*  
*Ajay*  
 12/3/25

*Ajay*  
 12/3/25

*n*