

2/54
c/55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 24/01/2025

No. F.6/DFS/MS/School/2025/SZ/ 59

To

Dr. Thomas George (Director),
St. Mary's Public School
530, Durga Vihar, Devli,
New Delhi-110062

Sub: Regarding issuance of FSC in r/o St. Mary's Public School located at 530, Durga Vihar, Devli, New Delhi-110062

Sir,

This has reference to your letter received through outdoor diary no 11267 dated 10/01/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 17.01.2025 in the presence of Dr. Thomas George (Director) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Overhead tank capacity 6,000 ltr provided against the required capacity of 10,000 ltrs.
2. Exit signage found removed at some places.
3. The management of building has made **addition two rooms at 3rd floor**. Hence, there is a material changed in the building Vis a Vis earlier FSC of this department.

The management is here by advised, either you may restore the earlier composition of building profile or otherwise submits application for sanction of building plans on common application form (CAF) with present floor wise occupancy, on the scales as mentioned in UBBL 2016, for further consideration in the matter.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.