



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

cl/B

No. F6/DFS/MS/WZ/2024/ 41

Dated:- 17/01/2025

To,

The Principal,
M. C. Primary Boys School,
Nangloi Village Inner-II, Delhi-110041.

Subj.:- Regarding issuance of fire safety certificate in respect of M. C. Primary Boys School, located at Nangloi, Village, Inner-II, Delhi-110041.

Sir,

Please refer to your letter no. nil dated 17/12/2024, received in this department through outdoor diary no. 10447 dated 18/12/2024 on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 13/01/2025 in the presence of Naresh Kumar (Principal) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/2013/2126 dated 30/08/2013 (copy enclosed).

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for issuance of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

Enclosed:- As above

(Atul Garg)
Director

Copy to :-

1. The Deputy Director, Municipal Corporation of Delhi, Civic Centre, Minto Road, Delhi-110002.

14/1/25
13/01/25

Remand DFA 94

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/School/2013/2126

Dated 30/08/13

To

The Principal,
M.C.D. Primary School,
Nangloi Village (inner side),
Delhi-110041.

Sub:- Inspection report in respect of M.C.D. Primary School, Nangloi village (inner side), Delhi-110041, from Fire Safety point of view.

Sir,

With reference to your letter No. Nil dated 10.07.2013 on the subject noted above, in this connection it is to inform you that the said school premises was inspected by the officer concerned of this department on 12.08.2013 in the presence of Smt. Suchitra (Principal).

During the course of inspection it was observed that the school premises comprised of three blocks i.e. G + 1 (First Block), G + 1 (Second Block) and G + 2 (Third Block) with plot area 5517m² and covered area 2030m² having 41 rooms and 2100 students (approximately). Only two Fire Extinguisher have been provided. The school is approachable to Fire Units.

The following shortcomings were observed during the time of inspection:-

1. G + 1 block has a single staircase of width 1.40mtr. against required 1.50mtr. The width of the staircase is required to be increased up to 1.50mtr. or one more staircase of minimum 0.75mtr width to be provided.
2. Fire extinguishers are inadequate. Five more Fire extinguishers of DCP type / Co2 type 2.50kg each one required to be provided.
3. First Aid Hose Reel in ground + two block at each floor not provided. ^{Tube} ~~Two~~ Hose Reel at each floor are required to be provided.
4. Over Head Terrace pump of 450lit/min. not provided.
5. Over Head tank of 10000 Lts. ~~Not~~ provided.
6. Exit signage is not provided.

The School premises is not meeting the requirement of Fire & Safety guidelines issued by the Directorate of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011.

In view of above, Fire Safety Certificate from Fire & Safety point of view cannot be considered at this stage. You are requested to apply for Fire Safety Certificate after compliance of conditions mentioned above.

V. Kental
(VIPIN KENTAL)
Dy. Chief Fire Officer,
Delhi Fire Service.
dcfowz.dlfire@nic.in
Ph: 011-23842505

Copy to:-

Director of Education,
North Delhi Municipal Corporation,
Dr. S.P.M., Civic Center, Minto Road,
New Delhi-110002.