

C 20



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजदी ७५  
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2024/WZ/ 22

Dated:- 15/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M. C. Primary Boys School, Located at Ghevra, New Delhi-110081, comprised of Ground + 01 Upper Floor only owned/occupied by M. C. Primary Boys School, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2019/1500 dated 23/07/2019. The said premise was re-inspected by the officer concerned of this department on 30/12/2024 in the presence of Sh. Khazan Singh (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 15/01/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 15/01/2025 at New Delhi by

*(Signature)*  
(Atul Garg)  
Director  
Tel No. 011-23414000

*(Signature)*  
13/01/25

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, M.C. Primary Boys School, Ghevra, New Delhi-110081.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name and address of the building: **M. C. Primary Boys School**, located at **Ghevra, New Delhi-110081**
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2019/1500 dated 23/07/2019
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01/03/2011
6. Date of inspection : 30/12/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Khazan Singh (Principal)
9. Year of Construction : 2008
10. Applicant's letter No. : email dated 12/12/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | D.O.E. Cr. No. 3298-3398 dated 01/03/2011/ as per FSC issued dated 23/07/2019 |  | Provided at site    | Remarks MR/NMR |
|------|---|---|--|---------------------|----------------|
| 1.   | Access of building  |   |  |                     |                |
|      | • Road width  | 06 m  |  | Provided            | MR             |
|      | • Gate width  | 4.5 m   |  | Provided            | MR             |
|      | • Width of internal road                                    | NA  |  | NA                  | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |   |  |                     |                |
|      | a. Number of staircases                                     |   |  |                     |                |
|      | • Upper floors  | 02  |  | 02                  | MR             |
|      | • Basements   | NA  |  | NA                  | NA             |
|      | b. Width of staircases                                      |   |  |                     |                |
|      | • Upper floors  | 1.5 m   |  | 1.70 m x 2          | MR             |
|      | • Basements   | NA  |  | NA                  | NA             |
|      | c. Protection of exits                                      |   |  |                     |                |
|      | • Fire check door   | NA  |  | NA                  | NA             |
|      | • Pressurization  | NA  |  | NA                  | NA             |
|      | d. No of continuous staircase to terrace                    | 01  |  | Provided            | MR             |
|      | e. Width Of Corridor  | NA  |  | NA                  | NA             |
|      | f. Door Size  | 1.0 m   |  | 1.0 m (Double Door) | MR             |
| 3.   | Compartmentation  |   |  |                     |                |
|      | • Fire check door   | NA  |  | NA                  | NA             |
|      | • Sealing of electrical shafts                              | NA  |  | NA                  | NA             |
|      | • Fire Rating of shaft door                                 | NA  |  | NA                  | NA             |
|      | • Water Curtain   | NA  |  | NA                  | NA             |
|      | • Fire Dampers  | NA  |  | NA                  | NA             |
| 4.   | Smoke managements System                                    |   |  |                     |                |
|      | • Basements   | NA  |  | NA                  | NA             |
|      | • Upper floors  | NA  |  | NA                  | NA             |
| 5.   | Fire Extinguishers  |   |  |                     |                |
|      | • Total numbers   | 04 nos.   |  | Provided            | MR             |
|      | • Types   | ABC & CO <sub>2</sub>   |  | Provided            | MR             |
|      | • ISI marking   | ISI Marked  |  | Provided            | MR             |

|     |  |    |    |    |
|-----|--|----|----|----|
| 6.  | First – Aid Hose Reel                        |    |    |    |
|     | • Total numbers on each floor                | NA | NA | NA |
|     | • Length of hose reel hose                   | NA | NA | NA |
|     | • Nozzle diameter                            | NA | NA | NA |
| 7.  | Automatic fire detection and alarming system |    |    |    |
|     | • Type of detectors                          | NA | NA | NA |
|     | • Location of Main Panel                     | NA | NA | NA |
|     | • Location of Repeater Panel                 | NA | NA | NA |
|     | • Alternate source of power                  | NA | NA | NA |
|     | • Hooters' Location                          | NA | NA | NA |
| 8.  | MOEFA  | NA | NA | NA |
| 9.  | Public Address System                        | NA | NA | NA |
| 10. | Automatic Sprinkler System                   |    |    |    |
|     | • Basements                                  | NA | NA | NA |
|     | • Upper Floor                                | NA | NA | NA |
|     | • Sprinkler above false ceiling              | NA | NA | NA |
| 11. | Internal Hydrants:                           |    |    |    |
|     | • Size of riser/down- comer                  | NA | NA | NA |
|     | • Number of hydrants per floor               | NA | NA | NA |
|     | • Hose Box                                   | NA | NA | NA |
| 12. | Yard Hydrants                                |    |    |    |
|     | • Total number of hydrants                   | NA | NA | NA |
|     | • Hose Box                                   | NA | NA | NA |
| 13. | Pumping Arrangements:                        |    |    |    |
|     | • Ground Level                               |    |    |    |
|     | • Discharge of main pump                     | NA | NA | NA |
|     | ➤ Head of main pump                          | NA | NA | NA |
|     | ➤ Number of main pumps                       | NA | NA | NA |
|     | ➤ Jockey pump out put                        | NA | NA | NA |
|     | ➤ Jockey pump head                           | NA | NA | NA |
|     | ➤ Standby Pump out put                       | NA | NA | NA |
|     | ➤ Standby Pump Head                          | NA | NA | NA |
|     | ➤ Auto Staring/Manual stopping               | NA | NA | NA |
|     | ➤ Pump House Access                          | NA | NA | NA |
|     | • Terrace level                              |    |    |    |
|     | ➤ Discharge of pump                          | NA | NA | NA |
|     | ➤ Head of the pump                           | NA | NA | NA |
|     | ➤ Power supply                               | NA | NA | NA |
|     | ➤ Auto starting of pump                      | NA | NA | NA |
| 14. | Captive water Storage for fire fighting:     |    |    |    |
|     | • Under ground tank capacity                 | NA | NA | NA |
|     | ➤ Draw off connection                        | NA | NA | NA |
|     | ➤ Fire service inlet                         | NA | NA | NA |
|     | ➤ Access to tank                             | NA | NA | NA |
|     | • Overhead Tank capacity                     | NA | NA | NA |
| 15. | Exit Signage                                 | NA | NA | NA |
| 16. | Provision of Lifts                           |    |    |    |
|     | ➤ Pressurization of Lift Shaft               | NA | NA | NA |
|     | ➤ Pressurization of lift lobby               | NA | NA | NA |
|     | ➤ Communication in lift Car                  | NA | NA | NA |
|     | ➤ Fireman's Grounding Switch                 | NA | NA | NA |
|     | ➤ Lift Signage                               | NA | NA | NA |
| 17. | Standby power supply                         | NA | NA | NA |
| 18. | Refuge Area                                  |    |    |    |
|     | ➤ Total area                                 | NA | NA | NA |
|     | ➤ Location                                   | NA | NA | NA |

|     |  |    |    |    |
|-----|--|----|----|----|
| 19. | Fire control room  |    |    |    |
|     | ➤ Detector system panel  | NA | NA | NA |
|     | ➤ Flow Switch Panel  | NA | NA | NA |
|     | ➤ PA System Panel  | NA | NA | NA |
|     | ➤ Battery backup   | NA | NA | NA |
|     | ➤ Building Floor Plans   | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2019/1500 dated 23/07/2019 is recommended.

Accordingly DFA is prepared for approval & signature please.

*DCFO (WZ)*

*Amrita*  
02/01/25  
Aman Kumar Lathar  
ADO (JWP)

*4*  
05/01/2025

*2025*

*efo*  
9/01/2025

*Director*  
9/1/25  
A.D./JWP

*Sir, F.T. letter is added for your signature pl.*

*Director*  
*M.A.*

*Amrita*  
13/01/25  
A.M. (WZ)