

130

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/school/2025/ 302

Dated: 30/04/2025

To,

Mrs. Babita (Incharge),
M.C Primary School,
W.E.A, 13 A, Block Channa Market,
Karol Bagh, New Delhi.

Sub: Application for issuance of fire safety certificate in respect of M.C Primary School,
W.E.A, 13 A, Block Channa Market, Karol Bagh, New Delhi.

Sir,

This has reference to letter no. nil dated 20/03/25 & DFS diary no. 14788 dated 21.03.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 21/04/25 in presence of Incharge and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/School/SZ/2022/101 dated 11/03/2022 (copy enclosed) have not been complied so far.

In view of above, FSC can't be issued till the compliance of the shortcomings issued vide aforesaid letter.

Yours faithfully

Encl: As above.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi -54.

c22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2022/ 101

Dated: - 11/03/2022

To,

The Incharge,
NDMC Primary School,
WEA, Channa Market, Karol Bagh,
New Delhi- 110005.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o NDMC Primary School, WEA, Channa Market, Karol Bagh New Delhi- 110008.

Sir,


With reference to your letter No. nil dated 10.02.2022 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 23.02.2022 in presence of Mrs. Babita, Incharge, to check the fire safety arrangements provided in the school building.

During the inspection, it was also observed that the school building is comprised of ground plus two upper floors. The upper floors are served by 02 nos. of staircases having width 1.50mts each. Fire safety arrangement such as fire extinguishers, overhead water tank etc. found provided. This department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2018/5029 dated 14.02.2018. However following shortcomings were observed: -

1. Terrace pump capacity 450 Lpm is required.
2. First Aid Hose Reel is required at each floor.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. This department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2018/5029 dated 14.02.2018. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully


(Sunil Chaudhary)

Dy. Chief Fire Officer
South Zone



Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054 .

For information please