



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-19

No. F6/DFS/MS/2025/School/ 251

Dated: 17 / 04 / 2025

To

The Principal
M.C.Primary School,
Hakikat Nagar, Delhi-110009.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary School, (I.D No.1253093), located at Hakikat Nagar, Delhi-110009.

Sir,

Please refer to your letter no. Nil dated 26.03.2025 and received in this department vide outdoor dairy no.15121 dated 28.03.2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 11.04.2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that as per earlier Fire Safety Certificate issued by this department letter of even no. F6/DFS/MS/2018/School/NDZ/1210 dated 24.05.2018 the building was comprised of ground floor only. Now the new building is constructed at site comprised of Ground & 02 upper floor only. At the time of inspection Smt. Lawrenceia Tigga (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 There is 02 nos. of staircases is provided width of 1.50m & 1.20m against the requirements of 1.50m each and both staircases continues from ground to terrace level.
- 2 Hose reel hose not provided.
- 3 Terrace level fire fighting pump capacity of 450lpm not provided.
- 4 Terrace level fire water tank capacity of 10,000ltrs not provided.
- 5 Exit signage not provided at strategic locations in the building.
- 6 Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, Rajputa Road, Delhi.